

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	GROUNDS	34E-E005-001	26259000													-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	CHILD CARE CENTRE	34E-E005-002	26259001	External	Ground Floor	DUPLICATE ENTRY - EXTERNAL										-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	CHILD CARE CENTRE	34E-E005-002	26259001	External	Ground Floor	EXT CHILD CARE CENTRE	50195	COMPRESSED SHEETING TO HOT WATER UNIT CUPBOARD - CHILD CARE CENTRE	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	CHILD CARE CENTRE	34E-E005-002	26259001	External	Ground Floor	EXT CHILD CARE CENTRE	50021	WALL SHEETING - GABLE ENDS AND EXTERNAL WALLS - CHILD CARE CENTRE	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	CHILD CARE CENTRE	34E-E005-002	26259001	External	Ground Floor	EXT CHILD CARE CENTRE	187516	WALL SHEETING TO EXTERNAL ABOVE 3 BACK DOORS - NORTHERN ELEVATION - CHILD CARE CENTRE	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	CHILD CARE CENTRE	34E-E005-002	26259001	External	Ground Floor	SOFFITS	187515	SOFFIT SHEETING TO VERANDAH CEILINGS - CHILD CARE CENTRE	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	CHILD CARE CENTRE	34E-E005-002	26259001	Internal	Ground Floor	INT CHILD CARE CENTRE	50046	VINYL FLOOR COVERING THROUGHOUT - G/FLOOR, CHILD CARE CENTRE	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	CHILD CARE CENTRE	34E-E005-002	26259001	Internal	Ground Floor	INT CHILD CARE CENTRE	50069	WALL SHEETING THROUGHOUT - G/FLOOR, CHILD CARE CENTRE	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 1	34E-E005-003	26259002			---										-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 1	34E-E005-003	26259002	External	Whole Building (asbestos free)	SHADE STRUCTURE 1	352733	BUILDING CONSTRUCTED 2006 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 2	34E-E005-004	26259003	External	Whole Building (asbestos free)	SHADE STRUCTURE 2	352734	BUILDING CONSTRUCTED 2000 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 2	34E-E005-004	26259003			---										-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 3	34E-E005-005	26259004			---										-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 3	34E-E005-005	26259004	External	Whole Building (asbestos free)	SHADE STRUCTURE 3	352735	BUILDING CONSTRUCTED 2006 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 4	34E-E005-006	26259005			---										-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 4	34E-E005-006	26259005	External	Whole Building (asbestos free)	SHADE STRUCTURE 4	352736	BUILDING CONSTRUCTED 2000 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 5	34E-E005-007	26259006			---										-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 5	34E-E005-007	26259006	External	Whole Building (asbestos free)	SHADE STRUCTURE 5	352737	BUILDING CONSTRUCTED 2006 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	STORE SHED 1	34E-E005-008	26259007			---										-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	STORE SHED 1	34E-E005-008	26259007	External	Whole Building (asbestos free)	STORE SHED 1	352738	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	STORE SHED 2	34E-E005-009	26259008	External	Whole Building (asbestos free)	STORE SHED 2	352739	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	STORE SHED 2	34E-E005-009	26259008			---										-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	STORE SHED 3	34E-E005-010	26259009			---										-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	STORE SHED 3	34E-E005-010	26259009	External	Whole Building (asbestos free)	STORE SHED 3	352740	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)			-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 6	34E-E005-011	26259010			---										-
Central Queensland	C&K BILOELA COMMUNITY CHILDCARE CENTRE (34E-E005) (26259000)	SHADE STRUCTURE 6	34E-E005-011	26259010	External	Whole Building (asbestos free)	SHADE STRUCTURE 6	352732	BUILDING CONSTRUCTED 2005 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)			-
Central Queensland	C&K WALKERSTON COMMUNITY KINDERGARTEN (34E-E017) (21510000)	GROUNDS	34E-E017-001	21510000													-
Central Queensland	C&K WALKERSTON COMMUNITY KINDERGARTEN (34E-E017) (21510000)	ECEC C&K	34E-E017-002	21510001	External	Other (refer to description)	EXTERNAL	135321	WALL SHEETING TO INFILL PANELS - EXTERNAL	Wall	Cement Based	To be determined	4	Presumed	18		-

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland	C&K WALKERSTON COMMUNITY KINDERGARTEN (34E-E017) (21510000)	ECEC C&K	34E-E017-002	21510001	Internal	Ground Floor	UNIT 1	135028	CEILING SHEETING - PEGBOARD	Ceiling	Cement Based	To be determined	4	Presumed	18	-	TOILETS, STOREROOM & LAUNDRY
Central Queensland	C&K WALKERSTON COMMUNITY KINDERGARTEN (34E-E017) (21510000)	ECEC C&K	34E-E017-002	21510001	Internal	Ground Floor	UNIT 1	135439	SHEETING TO INTERNAL WALLS & INFILL PANELS	Wall	Cement Based	To be determined	4	Presumed	18	-	
Central Queensland	C&K WALKERSTON COMMUNITY KINDERGARTEN (34E-E017) (21510000)	ECEC C&K	34E-E017-002	21510001	External	Other (refer to description)	EXTERNAL	135131	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
Central Queensland	C&K WALKERSTON COMMUNITY KINDERGARTEN (34E-E017) (21510000)	ECEC C&K	34E-E017-002	21510001	Internal	Ground Floor	MAIN ROOM									-	
Central Queensland	C&K WALKERSTON COMMUNITY KINDERGARTEN (34E-E017) (21510000)	STORAGE SHED	34E-E017-003	21510002												-	
Central Queensland	C&K WALKERSTON COMMUNITY KINDERGARTEN (34E-E017) (21510000)	SAND PIT COVER	34E-E017-004	21510003												-	
Central Queensland	C&K WALKERSTON COMMUNITY KINDERGARTEN (34E-E017) (21510000)	PLAY FORT & COVER	34E-E017-005	21510004												-	
Central Queensland	SHAKESPEARE CHILD & FAMILY CENTRE / GEORGE ST N'HOOD CENTRE (MACKAY) (34E-E016) (21514000)	** Site - Grounds	21514000	21514000												-	
Central Queensland	SHAKESPEARE CHILD & FAMILY CENTRE / GEORGE ST N'HOOD CENTRE (MACKAY) (34E-E016) (21514000)	PRE SCHOOL UNIT 1	21514001	21514001	Internal	Ground Floor	UNIT 1	135470	CEILING SHEETING (PEGBOARD & FLAT)	Ceiling	Cement Based	Not determined	4	Removed	18	-	
Central Queensland	SHAKESPEARE CHILD & FAMILY CENTRE / GEORGE ST N'HOOD CENTRE (MACKAY) (34E-E016) (21514000)	PRE SCHOOL UNIT 1	21514001	21514001	Internal	Ground Floor	UNIT 1	135456	WALL SHEETING - INTERNAL	Wall	Cement Based	Not determined	4	Removed	18	-	
Central Queensland	SHAKESPEARE CHILD & FAMILY CENTRE / GEORGE ST N'HOOD CENTRE (MACKAY) (34E-E016) (21514000)	PRE SCHOOL UNIT 1	21514001	21514001	Internal	Ground Floor	UNIT 1	135585	WALL SHEETING - EXTERNAL INFILL PANELS	Wall	Cement Based	Not determined	4	Removed	18	-	
Central Queensland	SHAKESPEARE CHILD & FAMILY CENTRE / GEORGE ST N'HOOD CENTRE (MACKAY) (34E-E016) (21514000)	STORE SHED	21514003	21514003												-	
Central Queensland	SHAKESPEARE CHILD & FAMILY CENTRE / GEORGE ST N'HOOD CENTRE (MACKAY) (34E-E016) (21514000)	SHADE STRUCTURE	21514006	21514006												-	
Central Queensland	SHAKESPEARE CHILD & FAMILY CENTRE / GEORGE ST N'HOOD CENTRE (MACKAY) (34E-E016) (21514000)	SHADE STRUCTURE 2	21514007	21514007												-	
Central Queensland	SHAKESPEARE CHILD & FAMILY CENTRE / GEORGE ST N'HOOD CENTRE (MACKAY) (34E-E016) (21514000)	STORE SHED 2	21514009	21514009												-	
Central Queensland	SLADE PT C&K COMM K/GARTEN	** Site - Grounds	53804000	53804000												-	
Central Queensland	SOUTH WEST MACKAY NBHC & BIRRALEE CHILD CARE CENTRE (34E-E027) (29334000)	** Site - Grounds	29334000	29334000												-	
Central Queensland	SOUTH WEST MACKAY NBHC & BIRRALEE CHILD CARE CENTRE (34E-E027) (29334000)	S/W N'HOOD CNTR	29334001	29334001	External	Whole Building (asbestos free)	BUILDING	62949	INSPECTION OF BUILDING- FOUND IT TO BE ASBESTOS FREE.	Other (refer to description)	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Central Queensland	SOUTH WEST MACKAY NBHC & BIRRALEE CHILD CARE CENTRE (34E-E027) (29334000)	BIRRALEE CHILD CAR	29334002	29334002	Internal	Ground Floor	ROOM 2	493353	VINYL FLOORING (CENTRE OF ROOM)	Floor Backing/Underlay	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Tested)		-	
Central Queensland	SOUTH WEST MACKAY NBHC & BIRRALEE CHILD CARE CENTRE (34E-E027) (29334000)	BIRRALEE CHILD CAR	29334002	29334002	Internal	Ground Floor	STOREROOM	354716	VINYL FLOORING - WEST END OF PLAY AREA	Floor	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Central Queensland	SOUTH WEST MACKAY NBHC & BIRRALEE CHILD CARE CENTRE (34E-E027) (29334000)	SAND PIT COVER	29334003	29334003	External	Whole Building (asbestos free)	SAND PIT COVER	354717	STEEL FRAME CONSTRUCTION - BUILT 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Central Queensland	SOUTH WEST MACKAY NBHC & BIRRALEE CHILD CARE CENTRE (34E-E027) (29334000)	STORE SHED	29334004	29334004	External	Whole Building (asbestos free)	STORE SHED	354718	METAL FRAME CONSTRUCTION - BUILT 1994 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Central Queensland	SOUTH WEST MACKAY NBHC & BIRRALEE CHILD CARE CENTRE (34E-E027) (29334000)	PLAYGROUND COVER	29334005	29334005	External	Whole Building (asbestos free)	SHADE CLOTH ROOF	354719	STEEL FRAME CONSTRUCTION & SHADECLOTH - BUILT 2001 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Central Queensland	SOUTH WEST MACKAY NBHC & BIRRALEE CHILD CARE CENTRE (34E-E027) (29334000)	JNR PLAYGRND COVER	29334006	29334006	External	Whole Building (asbestos free)	JUNIOR PLAY COVER	354720	METAL FRAME CONSTRUCTION - BUILT 2001 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Central Queensland	SOUTH WEST MACKAY NBHC & BIRRALEE CHILD CARE CENTRE (34E-E027) (29334000)	08 - GARDEN SHED	34E-E027-008	29334007												-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	GROUNDS	34E-E024-001	22712000													-
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	ECEC C&K	34E-E024-002	22712001	External	Ground Floor	PRESCHOOL (EXT)	165780	WALL SHEETING TO HAND RAILS - PRESCHOOL	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	ECEC C&K	34E-E024-002	22712001	Internal	Ground Floor	PRESCHOOL (INT)	165758	VINYL FLOOR SHEETING (GREEN FLECK) - PRESCHOOL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	ECEC C&K	34E-E024-002	22712001	Internal	Ground Floor	KITCHEN/TOILETS	376782	VINYL FLOOR SHEETING (GREY) INSTALLED 2007 - TOILETS/CHANGE/KITCHEN	Floor Finish/Covering	Vinyl Sheeting (includes backing)	Not Required	NA	Not Present(Not Tested)		-	
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	ECEC C&K	34E-E024-002	22712001	Internal	Ground Floor	KITCHEN/TOILETS	165862	WALL SHEETING - TOILETS	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	ECEC C&K	34E-E024-002	22712001	External	Ground Floor	PRESCHOOL (EXT)	165725	WALL SHEETING TO EXTERNAL - PRESCHOOL	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	ECEC C&K	34E-E024-002	22712001	External	Ground Floor	FASCIA/BARGE	165879	FASCIA/BARGE SHEETING - PRESCHOOL	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	ECEC C&K	34E-E024-002	22712001	External	Other (refer to description)	SIGN	165824	SHEETING TO SIGN - PRESCHOOL	Sign	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	ECEC C&K	34E-E024-002	22712001	External	Other (refer to description)	SUN SHADE	165819	SHEETING TO SUNSHADE - PRESCHOOL	Sun Hood	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	STORE SHED	34E-E024-003	22712002	External	Whole Building (asbestos free)	STORE SHED	165635	BUILDING CONSTRUCTED POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	SAND PIT/FORT	34E-E024-004	22712003	External	Whole Building (asbestos free)	SAND PIT/FORT	165826	BUILDING CONSTRUCTED POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Central Queensland	C&K LEICHHARDT COMMUNITY KINDERGARTEN (ROCKHAMPTON) (34E-E024) (22712000)	COVERED AREA	34E-E024-005	22712005	External	Other (refer to description)	STRUCTURE	357339	BUILDING CONSTRUCTED 2007 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	GROUNDS	34E-E033-001	25598000													-
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	NORTH WESTERN SHOWER CHANGE ROOM	428143	GREY BLUE SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	To be determined	3	Presumed	76	-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	NORTHERN GLA (GENERAL WEARING AREA)	428144	BLUE GREY SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	To be determined	3	Presumed	76	-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	PAINT ROOM - CENTRAL NORTH END	44100	CEILING SHEETS TO PAINT ROOM AREA	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	SOUTH WEST LAUNDRY	428152	GREY BLUE SHEET VINYL - SAMPLED NORTH WEST CORNER IN FRONT OF CUPBOARD	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	3	Not Present(Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	SOUTHERN GLA	44135	GREY/BLUE VINYL FLOOR SHEETING	Floor	Vinyl Tiles	To be determined	4	Presumed	18	-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	SOUTHERN NAPPY CHANGING ROOM	428151	GREY BLUE SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	3	Not Present(Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	TOILET/SHOWER	44127	COMPRESSED PANEL FORMING PARTITION IN NORTHERN END SHOWER/TOILET AREA	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	WESTERN OFFICE	428135	GREY BLUE SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	To be determined	3	Presumed	76	-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	EASTERN KITCHEN	428148	BLUE/GRAY SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	3	Not Present(Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	WESTERN FOYER	428138	GREY BLUE SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	To be determined	3	Presumed	76	-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	External	Other (refer to description)	CHANGE ROOM	361838	EXTERNAL WALL SHEETING TO CHANGE/NAPPIE ROOM, S/SIDE	Wall	Cement Based	No asbestos detected (NAD)	3	Not Present(Tested)		-	WELL PAINTED
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	NORTH EAST STORE	428146	BLUE GREY SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	3	Not Present(Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	External	Other (refer to description)	CHANGE ROOM	452981	EXTERNAL WALL OUTSIDE CHANGE ROOM EAST END - SAMPLED ABOVE DRAIN	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	HALLWAY	428155	GREY BLUE SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	To be determined	3	Presumed	76	-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	LAUNDRY STORE AREA	428153	GREY BLUE SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	To be determined	3	Presumed	76	-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	External	Roof Level 1	SOFFIT	44173	SHEETING TO GABLE ENDS SOUTH & NORTH.	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	External	Roof Level 1	SOFFIT	44150	SOFFIT SHEETING TO ACCESS DOORS (3) ON SOUTHERN SIDE OF BUILDING	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	External	Roof Level 1	FASCIA	44210	SHEETS APPLIED TO FORM FASCIA BARGE TO NORTH, SOUTH, EAST & WEST SIDES OF BUILDING	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	MAIN BUILDING	34E-E033-002	25598001	Internal	Ground Floor	NORTH WESTERN OFFICE	428137	GREY BLUE SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	To be determined	3	Presumed	76	-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	STORAGE SHED	34E-E033-003	25598002	External	Whole Building (asbestos free)	STORAGE SHED	44088	NIL ASBESTOS IDENTIFIED. BUILDING CONSTRUCTED POST 1990	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	GARDEN SHED	34E-E033-004	25598003	External	Level 24	GARDEN SHED	187422	BUILDING CONSTRUCTED POST 1990 - NIL ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	SHADE STRUCTURE 1	34E-E033-005	25598004	External	Whole Building (asbestos free)	SHADE STRUCTURE 1	187423	BUILDING CONSTRUCTED POST 1990 - NIL ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	SHADE STRUCTURE 2	34E-E033-006	25598005	External	Whole Building (asbestos free)	SHADE STRUCTURE 2	187424	BUILDING CONSTRUCTED POST 1990 - NIL ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	SHADE STRUCTURE 3	34E-E033-007	25598006	External	Whole Building (asbestos free)	SHADE STRUCTURE 3	187425	BUILDING CONSTRUCTED POST 1990 - NIL ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	SHADE STRUCTURE 4	34E-E033-008	25598007	External	Whole Building (asbestos free)	SHADE STRUCTURE 4	187426	BUILDING CONSTRUCTED POST 1990 - NIL ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Darling Downs South West	TOOWOOMBA CHILD CARE CENTRE (34E-E033) (25598000)	SHADE STRUCTURE 5	34E-E033-009	25598008	External	Whole Building (asbestos free)	SHADE STRUCTURE 5	187427	BUILDING CONSTRUCTED POST 1990 - NIL ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	SHADE STRUCTURE 1	20895008	20895008												-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	STORAGE SHED 1	20895009	20895009												-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	SHADE STRUCTURE 2	20895010	20895010												-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	GROUNDS	34E-E020-001	20895000												-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 1	34E-E020-002	20895001	Internal	Ground Floor	STAFF TOILET	351343	WALL SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 1	34E-E020-002	20895001	Internal	Ground Floor	STUDENT TOILETS	351345	WALL SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 1	34E-E020-002	20895001	Internal	Ground Floor	CLEANERS STORE	351344	WALL SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 1	34E-E020-002	20895001	External	Ground Floor	VERANDAHS SOUTH/WESTERN ELEVATION	351340	WALL SHEETING - WING WALLS TO THE SOUTH/WESTERN AND SOUTHEASTERN ELEVATIONS	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 1	34E-E020-002	20895001	External	Ground Floor	VERANDAHS SOUTH/WESTERN ELEVATION	15719	WALL SHEETING - BALUSTRADE	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 1	34E-E020-002	20895001	External	Ground Floor	PERIMETER	15613	WALL SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 1	34E-E020-002	20895001	External	Ground Floor	PERIMETER	351341	SUNHOOD SHEETING - NORTHERN AND WESTERN ELEVATIONS	Sun Hood	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 1	34E-E020-002	20895001	Internal	Ground Floor	THROUGHOUT BUILDING	351342	FLOOR SHEETING - ACTIVITES, KITCHEN, STAFF TOILET, CLEANERS ROOM, STUDENT TOILET AND EQUIPMENT STORE	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 2	34E-E020-003	20895002	External	Ground Floor	PERIMETER	354391	WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 2	34E-E020-003	20895002	Internal	Ground Floor	TOILET	15660	CEILING SHEETING - TOILET AREA	Ceiling	Cement Based	Not determined	4	Removed	18	-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 2	34E-E020-003	20895002	Internal	Ground Floor	STUDENT TOILET	15677	WALL PARTITIONS SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 2	34E-E020-003	20895002	Internal	Ground Floor	STORE ROOM	15713	CEILING SHEETING	Ceiling	Cement Based	Not determined	4	Removed	18	-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 2	34E-E020-003	20895002	Internal	Ground Floor	OFFICE	15710	CEILING SHEETING - OFFICE AREA	Ceiling	Cement Based	Not determined	4	Removed	18	-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 2	34E-E020-003	20895002	Internal	Ground Floor	EQUIPMENT STORE	351334	CEILING SHEETING - ACCESS PANEL	Ceiling Access Panel	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 2	34E-E020-003	20895002	Internal	Ground Floor	EQUIPMENT STORE	15705	CEILING SHEETING	Ceiling	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 2	34E-E020-003	20895002	External	Ground Floor	PERIMETER	354392	SOFFIT SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 2	34E-E020-003	20895002	External	Ground Floor	PERIMETER	15651	ALL SHEETING (Disposed in error, re entered)	Wall	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Darling Downs South West	NANANGO COMMUNITY HUB (34E-E020) (20895000)	ECEC BUILDING 2	34E-E020-003	20895002	Internal	Ground Floor	ACTIVITY AREA	15609	PERFORATED CEILING SHEETING - INCLUDING STOREROOM, ENTRY & OFFICE	Ceiling	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Darling Downs South West	TOOWOOMBA EARLY CHILDHOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	COMMUNITIES ECEC	22343001	22343001	Internal	Ground Floor	NW STORE ROOM	356825	CEILING ACCESS PANEL	Ceiling Access Panel	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Darling Downs South West	TOOWOOMBA EARLY CHILDHOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	COMMUNITIES ECEC	22343001	22343001	Internal	Ground Floor	INFANTS TOILETS	164189	COMPRESSED AC TOILET DIVIDERS TO INFANTS TOILETS	Wall	Cement Based	Not determined	4	Removed	18	-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	COMMUNITIES ECEC	22343001	22343001	Internal	Ground Floor	ALL ROOMS	164149	PERFORATED AND AC SHEETING TO CEILINGS OF ALL ROOMS	Ceiling	Cement Based	Not determined	4	Removed	18	-	
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	COMMUNITIES ECEC	22343001	22343001	Internal	Ground Floor	ALL ROOMS	164084	ALL WALL SHEETING TO ALL INTERNAL WALL AC SHEETINGS	Wall	Cement Based	Not determined	4	Removed	18	-	
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	COMMUNITIES ECEC	22343001	22343001	External	Ground Floor	EXTERNAL WALLS	164059	WALL SHEETING BETWEEN BRICK WORK, TIMBERWORK AND ALUMINIUMWINDOWS SHEETED WITH AC	Wall	Cement Based	Not determined	4	Removed	18	-	
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	COMMUNITIES ECEC	22343001	22343001	External	Whole Building (asbestos free)	COMMUNITIES ECEC	477781	BLDG CONSTRUCTED 1994 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	COMMUNITIES ECEC	22343001	22343001	External	Roof Level 1	SOFFITS	164054	SOFFITS TO PERIMETER OF MAIN ROOF INCLUDING ENTRY AND VERANDAH	Gable/Soffit/Fascia	Cement Based	Not determined	4	Removed	18	-	
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	COMMUNITIES ECEC	22343001	22343001		Ground Floor	ENTRY	164188	MILLBOARD TO SWITCHBOARD TO MAIN ENTRY	Insulation/Fill	Millboard	Not determined	4	Removed	64	-	
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	COMMUNITIES ECEC	22343001	22343001		Ground Floor	SOUTH SIGN	164025	TOOWOOMBA NORTH PRE-SCHOOL CENTRE SIGN IS COMPRESSED AC	Sign	Cement Based	Not determined	4	Removed	18	-	
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	SHADE STRCUTURE 3	22343007	22343007	External	Whole Building (asbestos free)	SHADE STRUCTURE 3	428104	CONSTRUCTED POST 1990 - PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	SHADE STRUCTURE 2	22343008	22343008	External	Whole Building (asbestos free)	SHADE STRUCTURE 2	428096	CONSTRUCTED POST 1990 - PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	SANDPIT SHADE STRCUTURE	22343009	22343009	External	Whole Building (asbestos free)	SANDPIT SHADE STRUCTURE - KULILA INDIGENOUS KINDERGARDEN	428087	CONSTRUCTED POST 1990 - PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	GARAGE	22343010	22343010	External	Whole Building (asbestos free)	GARAGE	428086	CONSTRUCTED POST 1990 - PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	GROUPS	34E-E034-001	22343000												-	
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	STORAGE SHED	34E-E034-003	22343002	External	Ground Floor	STORE SHED	356829	NIL ASBESTOS IDENTIFIED - METAL CONSTRUCTION	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	COVD OUTDOOR AREA	34E-E034-006	22343005	External	Whole Building (asbestos free)	COVD OUTDOOR AREA	355664	METAL CONSTRUCTION BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
Darling Downs South West	TOOWOOMBA EARLY CHILDHOOD EDUCATION & CARE CENTRE (34E-E034) (22343000)	COVD OUTDOOR AREA	34E-E034-006	22343005			---									-	
Far North Queensland	WARATAH DRIVE CHILD CARE CENTRE (CAIRNS) (34E-E007) (25956000)	GROUPS	34E-E007-001	25956000												-	
Far North Queensland	WARATAH DRIVE CHILD CARE CENTRE (CAIRNS) (34E-E007) (25956000)	CHILD CARE CENTRE	34E-E007-002	25956001	External	Ground Floor	EXTERNAL VERANDAH - CHILD CARE CENTRE	429065	EXTERNAL - CEILING LINING - WEST VERANDAH -	Ceiling	Cement Based	No asbestos detected (NAD)	NA	Not Present(Tested)		-	Building built post 1990
Far North Queensland	WARATAH DRIVE CHILD CARE CENTRE (CAIRNS) (34E-E007) (25956000)	CHILD CARE CENTRE	34E-E007-002	25956001	Internal	Ground Floor	STOREROOM	429067	INTERNAL - CEILING LINING - STOREROOM - CHILD CARE CENTRE -	Ceiling	Cement Based	No asbestos detected (NAD)	NA	Not Present(Tested)		-	Building built post 1990
Far North Queensland	WARATAH DRIVE CHILD CARE CENTRE (CAIRNS) (34E-E007) (25956000)	CHILD CARE CENTRE	34E-E007-002	25956001	Internal	Whole Building (asbestos free)	FRONT ENTRANCE	386242	INFILL WALL PANELS - FRONT ENTRANCE - CHILD CARE CENTRE - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Far North Queensland	WARATAH DRIVE CHILD CARE CENTRE (CAIRNS) (34E-E007) (25956000)	STORE SHED 1	34E-E007-003	25956002												-	
Far North Queensland	WARATAH DRIVE CHILD CARE CENTRE (CAIRNS) (34E-E007) (25956000)	SHADE STRUCTURE 1	34E-E007-004	25956003												-	
Far North Queensland	WARATAH DRIVE CHILD CARE CENTRE (CAIRNS) (34E-E007) (25956000)	STORE SHED 2	34E-E007-005	25956004												-	
Far North Queensland	WARATAH DRIVE CHILD CARE CENTRE (CAIRNS) (34E-E007) (25956000)	07 - SHADE STRUCTURE 2	34E-E007-007	25956006												-	
Far North Queensland	WARATAH DRIVE CHILD CARE CENTRE (CAIRNS) (34E-E007) (25956000)	08 - SHADE STRUCTURE 3	34E-E007-008	25956007												-	
Far North Queensland	WESTERN CAPE COLLEGE - WEIPA - PREP YEAR (34U-1407) (21973)	00 - WESTERN CAPE COLLEGE - WEIPA - PREP YEAR - GROUNDS	34U-1407-000	21973000	External	Site / Grounds	GROUNDS	180257	COMPRESSED SHEET SIGN - ENTRANCE	Sign	Cement Based	To be determined	4	Presumed	18	-	
Far North Queensland	WESTERN CAPE COLLEGE - WEIPA - PREP YEAR (34U-1407) (21973)	24 - PREP YEAR BUILDING	34U-1407-024	21973001	Internal	Ground Floor	INTERNAL	150636	VINYL TILES - INTERNAL - PRE SCHOOL	Floor	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Far North Queensland	WESTERN CAPE COLLEGE - WEIPA - PREP YEAR (34U-1407) (21973)	24 - PREP YEAR BUILDING	34U-1407-024	21973001	External	Roof Level 1	FASCIA	150549	FASCIA - PRE SCHOOL	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
Far North Queensland	WESTERN CAPE COLLEGE - WEIPA - PREP YEAR (34U-1407) (21973)	24 - PREP YEAR BUILDING	34U-1407-024	21973001	Internal	Ground Floor	INTERNAL	150798	CEILING LINING - INTERNAL - PRE SCHOOL	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
Far North Queensland	WESTERN CAPE COLLEGE - WEIPA - PREP YEAR (34U-1407) (21973)	24 - PREP YEAR BUILDING	34U-1407-024	21973001	External	Ground Floor	SUNHOODS	150376	SUNHOODS - COMPRESSED SHEET - PRE SCHOOL	Sun Hood	Cement Based	To be determined	4	Presumed	18	-	
Far North Queensland	WESTERN CAPE COLLEGE - WEIPA - PREP YEAR (34U-1407) (21973)	24 - PREP YEAR BUILDING	34U-1407-024	21973001	External	Ground Floor	EXTERNAL	150662	EXTERNAL INFILL PANELS - ABOVE WINDOWS - WEST END	Wall	Cement Based	To be determined	4	Presumed	18	-	
Far North Queensland	WESTERN CAPE COLLEGE - WEIPA - PREP YEAR (34U-1407) (21973)	24 - PREP YEAR BUILDING	34U-1407-024	21973001	Internal	Ground Floor	INTERNAL	150812	INTERNAL PARTITION LININGS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
Far North Queensland	WESTERN CAPE COLLEGE - WEIPA - PREP YEAR (34U-1407) (21973)	24 - PREP YEAR BUILDING	34U-1407-024	21973001	External	Ground Floor	EAVES/VERANDAH	150602	EXTERNAL - CEILING CLADDING - REAR PATIO - PRE SCHOOL	Ceiling	Cement Based	No asbestos detected (NAD)	NA	Not Present(Tested)		-	CY-7398 28/02/2011 R. HAMMER
Far North Queensland	WESTERN CAPE COLLEGE - WEIPA - PREP YEAR (34U-1407) (21973)	24 - PREP YEAR BUILDING	34U-1407-024	21973001	External	Ground Floor	COVERED PLAY AREA	150446	CEILING LINING - COVERED PLAY AREA	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
Far North Queensland	WESTERN CAPE COLLEGE - WEIPA - PREP YEAR (34U-1407) (21973)	I99 - SHADE SAILS AND COVERS	34U-1407-0199	21973004	External	Other (refer to description)	SHADE STRUCTURE	150597	ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Far North Queensland	WESTERN CAPE COLLEGE - WEIPA - PREP YEAR (34U-1407) (21973)	B99 - SHED - GARDEN	34U-1407-B99	21973002	External	Whole Building (asbestos free)	GARDEN SHED	150361	ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	** Site - Grounds	24120000	24120000	External	Ground Floor	EXTERNAL	74741	METAL SHEETING - NO ASBESTOS DETECTED	Wall	Other (refer to description)	Not Required	4	Not Present(Not Tested)		-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	** Site - Grounds	24120000	24120000	External	Ground Floor	EXTERNAL	74784	METAL SHEETING - NO ASBESTOS DETECTED	Wall	Other (refer to description)	Not Required	4	Not Present(Not Tested)		-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	** Site - Grounds	24120000	24120000	External	Ground Floor	EXTERNAL	74776	METAL SHEETING - NO ASBESTOS DETECTED	Wall	Other (refer to description)	Not Required	4	Not Present(Not Tested)		-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	External	Roof Level 2	EXTERNAL WEST	32837	SHEETING BELOW ROOF LEVELS 2 AND 1 SIM SAMPLE #SC1774	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	Internal	Ground Floor	KITCHEN	32908	SHEETS BEHIND STOVE & HAND BASINS SIM SAMPLE #SC1774	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	External	Ground Floor	EXTERNAL WEST	32997	SHEETING SIM SAMPLE #SC1774	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	External	Ground Floor	SOUTH VERANDAH	32986	SHEETING UNDER ROOF PHOTO 1/3 SIM SAMPLE #SC1774	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	External	Roof Level 1	EXTERNAL WEST	32812	SHEETING SIM SAMPLE #SC1774	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	External	Roof Level 2	EXTERNAL EAST	32825	SHEETING BELOW ROOF LEVEL 2 PHOTO 1/1 SIM SAMPLE #SC1774	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	Internal	Ground Floor	2 - 3 TOILETS	32933	SHEETS BELOW SKYLIGHT	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	Internal	Ground Floor	3 - 5 TOILETS	33013	SHEETS BELOW SKYLIGHT	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	External	Ground Floor	EXTERNAL SOUTH	33038	AC SHEETING ABOVE DOORS BLOCKWORK AND WINDOWS SAMPLE #SC1774	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	Internal	Ground Floor	KITCHEN	315296	SHEET VINYL FLOOR TO KITCHEN	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	3	Removed		-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	Internal	Ground Floor	LAUNDRY	32823	SHEETING AROUND SLIDING DOOR SIM SAMPLE #SC1774	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	Internal	Ground Floor	NURSERY	32877	SHEET VINYL SIM SAMPLE #SC1776	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	3	Removed		-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	Internal	Ground Floor	STAFF ROOM	32971	SHEET VINYL SAMPLE #SC1776	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	3	Removed		-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	Internal	Ground Floor	STAFF TOIL/SHW	32867	TOILET PARTITION SAMPLE #SC1775	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	Internal	Ground Floor	STAFF TOIL/SHW	32788	SHEETING SOUTH WALL SIM SAMPLE #SC1774	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	Internal	Ground Floor	KINDY ROOMS & HALL	315295	SHEET VINYL TO FLOOR OF ROOMS SIM SAMPLE 25301	Floor Finish/Covering	Vinyl Sheeting (includes backing)	Not determined	3	Removed	62	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	External	Ground Floor	EXT.NTH. ENTRY	32922	SHEETING AROUND STEEL COLUMNS PHOTO 1/2	Wall	Cement Based	To be determined	3	Presumed	18	-	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	Internal	Ground Floor	PUBLIC TOILET	32888	SHEETING SIM SAMPLE #SC1774	Wall	Cement Based	To be determined	4	Presumed	18	-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments	
Metropolitan	GROVES CHRISTIAN COLLEGE EARLY LEARNING CENTRE (34E-E013) (24120000)	CENTRE	24120001	24120001	External	Ground Floor	EXTERNAL NORTH	32932	SHEETING ABOVE BLOCK WORK AND WINDOWS	Wall	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	GROUPS	34E-E037-001	25186000													-	
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	CHILD CARE	34E-E037-002	25186001	Internal	Ground Floor	3-5 YEARS PLAY AREA	380454	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Tested)			-	
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	CHILD CARE	34E-E037-002	25186001	External	Ground Floor	DOWNSTAIRS OPEN AREA	42212	WALL SHEETING - TOP OF BLOCK WORK	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-	
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	CHILD CARE	34E-E037-002	25186001	External	Ground Floor	DRAIN TRAP SURROUNDS	42536	DRAIN SURROUND X 1 AT SOUTH WEST CORNER OF BUILDING. SEE PHOTO 01	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)	4	Removed			-	
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	CHILD CARE	34E-E037-002	25186001	Internal	Ground Floor	HOT WATER SERVICE AND CLEANER'S CUPBOARDS	42336	WALL PARTITION - BETWEEN HOT WATER SERVICE AND CLEANER'S CUPBOARDS	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-	
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	CHILD CARE	34E-E037-002	25186001	Internal	Ground Floor	KITCHEN	42267	WALL SHEETING - AROUND DOOR WAY	Wall	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	CHILD CARE	34E-E037-002	25186001	Internal	Ground Floor	LAUNDRY	380455	VINYL FLOOR SHEETING	Floor	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Tested)			-	
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	CHILD CARE	34E-E037-002	25186001	Internal	Level 1	INFANT TOILETS	42331	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	CHILD CARE	34E-E037-002	25186001	Internal	Level 1	KITCHEN	42376	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	CHILD CARE	34E-E037-002	25186001	Internal	Level 1	BABY WASH ROOM	42256	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	SHADE STRUCTURE	34E-E037-003	25186002													-	
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	STORAGE SHED	34E-E037-004	25186003		Ground Floor	STORAGE SHED	24525	STRUCTURE CONSTRUCTED OF METAL	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)			-	
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	SHADE STRUCTURE	34E-E037-005	25186004													-	
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	SHADE STRUCTURE	34E-E037-006	25186005													-	
Metropolitan	WINDSOR CHILD CARE CENTRE (34E-E037) (25186000)	LAUNDRY	34E-E037-007	25186006													-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	GROUPS	34E-E036-001	29370000													-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Level 1	STAFFROOM	62987	WALL SHEETING	Wall	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Level 1	KITCHEN	62913	SPLASHBACK SHEETING - SINK UNIT	Wall	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Level 1	KITCHEN	62997	CEILING SHEETING - TO STOVE NOOK	Ceiling	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Level 1	PAINTING ROOM	62975	WALL SHEETING - ABOVE WINDOWS AND NORTHERN ELEVATION	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Level 1	PAINTING ROOM	62922	CEILING SHEETING	Ceiling	Cement Based	Mixed	4	Confirmed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Level 1	STAFF BATHROOM	420886	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Other (refer to description)	STAFF BATHROOM AND WASH ROOM	63027	WALL SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Level 1	STAFF LAUNDRY	63023	WALL SHEETING - WESTERN ELEVATION	Ceiling	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Level 1	KITCHEN	62920	WALL SHEETING - TO PANTRY AT DOOR WAY	Wall	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Ground Floor	DEBRIS	62973	SHEETING DEBRIS UNDER BUILDING	Stored Material	Cement Based	Not determined	4	Removed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Level 1	STAFF LAUNDRY	63044	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Level 1	ENCLOSED VERANDAH	63134	WALL PARTITION - WESTERN ELEVATION	Wall	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Ground Floor	LAUNDRY	62971	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	External	Site / Grounds	PLAY AREA	63113	WALL SHEETING - BLACK BOARDS	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	External	Roof Level 1	EXTERNAL WALL SHEETING	63010	WALL SHEETING - EASTERN ELEVATION	Wall	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	External	Level 1	SOFFITS	62935	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-		

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	External	Level 1	EXTERNAL WALL SHEETING	62970	WALL SHEETING - ABOVE LATICE WORK - WESTERN ELEVATION	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	External	Level 1	EXTERNAL WALL SHEETING	63126	WALL SHEETING - AROUND AIR CONDITIONER - EASTERN ELEVATION	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	External	Ground Floor	EXTERNAL WALL SHEETING	63008	WALL SHEETING - EXTERIOR TO LAUNDRY - BEHIND VERANDAH	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Ground Floor	LAUNDRY	63080	WALL SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	CHILD CARE CENTRE	34E-E036-002	29370001	Internal	Level 1	INFANTS TOILETS	62939	WALL SHEETING - WESTERN ELEVATION	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	FRONT STORAGE SHED	34E-E036-003	29370002		Ground Floor	BUILDING FRONT	62991	STRUCTURE CONSTRUCTED OF METAL	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	BACK STROAGE SHED	34E-E036-004	29370003		Ground Floor	BUILDING BACK	62921	STRUCTURE CONSTRUCTED OF METAL	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	COVERED AREA	34E-E036-005	29370004												-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	SHADE STRUCTURE	34E-E036-006	29370005												-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	SHADE STRUCTURE	34E-E036-007	29370006												-	
Metropolitan	C&K WILSTON COMMUNITY CHILDCARE CENTRE (34E-E036) (29370000)	SANDPIT SHADE CVR	34E-E036-008	29370007												-	
Metropolitan	CHERMESIDE PREP YEAR (34A-4009) (21059)	01 - GROUNDS	34A-4009-001	21059000												-	
Metropolitan	CHERMESIDE PREP YEAR (34A-4009) (21059)	02 - PREP YEAR	34A-4009-002	21059001												-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	GROUNDS	34E-E010-001	23822000												-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	CENTRE	34E-E010-002	23822001	External	Ground Floor	MAIN ENTRANCEFOYER	30580	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	CENTRE	34E-E010-002	23822001	Internal	Ground Floor	INTERNAL CEILING SHEETING	356302	CEILING SHEETING	Ceiling	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	CENTRE	34E-E010-002	23822001	Internal	Ground Floor	STAFF LOCKERS AND TOILET	30487	WALL PARTITION - BETWEEN CUBICLES TO LOCKERS AND TOILET	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	CENTRE	34E-E010-002	23822001	External	Ground Floor	MAIN ENTRANCEFOYER	30595	WALL SHEETING	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	CENTRE	34E-E010-002	23822001	External	Ground Floor	EXTERNAL WALL SHEETING	30352	WALL SHEETING - OUTSIDE PLAY AREA 2	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	CENTRE	34E-E010-002	23822001	External	Ground Floor	EXTERNAL WALL SHEETING	30443	WALL SHEETING - OVER WINDOW OUTSIDE STAFF LOCKER ROOM	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	CENTRE	34E-E010-002	23822001	External	Ground Floor	EXTERNAL WALL SHEETING	430167	WALL SHEETING - COLUMN ADJACENT TO MAIN ENTRANCE	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	CENTRE	34E-E010-002	23822001	External	Ground Floor	EXTERNAL WALL SHEETING	30523	WALL SHEETING - STOREROOM OUSIDE THE MAIN ENTRY	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	SANDPIT COVER	34E-E010-003	23822002	External	Ground Floor	COVER									-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	SHADE STRUCTURE	34E-E010-004	23822003	External	Ground Floor	SHADE STRUCTURE	330408	STRUCTURE CONSTRUCTED OF METAL - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	SHADE STRUCTURE	34E-E010-005	23822004	External	Ground Floor	SHADE STRUCTURE	330409	SHADE STRUCTURE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	GOODNA COMMUNITY CHILD CARE CENTRE (34E-E010) (23822000)	PERGOLA NO 1	34E-E010-006	23822005												-	
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	GROUNDS	34E-E012-001	29296000	External	Site / Grounds	EXTERNAL	75998	PLY WOOD SHEETING TO SIGN - SITE IDENTIFICATION - HIGHGATE HILL KOOLYANGARRA (ASBESTOS FREE)	Sign	Other (refer to description)	Not Required	5	Not Present(Not Tested)		-	
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	Internal	Ground Floor	INTERNAL FLOOR COVERINGS	62791	VINYL FLOOR TILES TO VARIOUS AREAS-KITCHEN, EAST END PLAY ROOM,ENTRY PHOTO 6 SAMPLE 1999	Floor	Vinyl Tiles	CHR - Chrysotile	4	Removed	18	-	
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	Internal	Ground Floor	LAUNDRY	62942	WALL SHEETING	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	Internal	Ground Floor	TOY ROOM	417919	CEILING SHEETING	Ceiling	Cement Based	To be determined	3	Presumed	18	-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments	
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	Internal	Ground Floor	TOILETS	62944	WALL SHEETING	Wall	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	Internal	Ground Floor	SLEEP AREA	62906	VINYL FLOOR TILES TO SLEEPING AREA ON NORTH EAST CORNER OF CHILD CARE UNIT	Floor	Vinyl Tiles	Not determined	4	Removed	18	-		
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	Internal	Ground Floor	PLAY AREA	62932	VINYL FLOOR TILES TO WESTERN END OF PLAY AREA IN CHILD CAREUNIT-PHOTO 7 SAMPLE 1998	Floor	Vinyl Tiles	CHR - Chrysotile	4	Removed	18	-		
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	Internal	Ground Floor	NURSERY ROOM	341741	CEILING SHEETING	Ceiling	Cement Based	To be determined	3	Presumed	18	-		
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	Internal	Ground Floor	INTERNAL FLOOR COVERINGS	62905	VINYL FLOOR TILES TO VARIOUS AREAS-ENTRY,LAUNDRY PRE ROOM PHOTO 5 SAMPLE 2000	Floor	Vinyl Tiles	CHR - Chrysotile	4	Removed	18	-		
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	Internal	Ground Floor	INTERNAL CEILING SHEETING	62907	CEILING SHEETING-EXCL GECKOS & POSSUMS RM,KOALAS RM,NURSERY RM AND TOY RM	Ceiling	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	Internal	Ground Floor	GECKOS AND POSSUMS ROOM	377898	PLASTER CEILING SHEETING	Ceiling	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-		
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	External	Roof Level 1	VENT PIPES	62954	VENT PIPE - SOUTH EASTERN CORNER	Drains/Pipes/Flues	Cement Based	To be determined	3	Presumed	18	-		
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	External	Ground Floor	SOFFITS	62918	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	External	Ground Floor	EXTERNAL WALL SHEETING	62927	WALL SHEETING - UNDER WINDOWS	Wall	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	KOOLYANGARRA EARLY LEARNING CENTRE (HIGHGATE HILL) (34E-E012) (29296000)	CENTRE	34E-E012-002	29296001	Internal	Ground Floor	KOALAS ROOM	377897	PLASTER CEILING SHEETING	Ceiling	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-		
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	COVERED AREA	34E-E035	20850006													-	
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	GROUNDS	34E-E035-001	20850000													-	
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	Internal	Ground Floor	FEMALE TOILET	184864	CISTERN ACCESS PANELS	Wall	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	Internal	Ground Floor	LAUNDRY	184862	WALL SHEETING -INIFLL PANEL - ABOVE HOT WATER UNIT	Wall	Cement Based	To be determined	4	Presumed	18	-		
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	Internal	Ground Floor	LAUNDRY	184863	VINYL FLOOR SHEETING (DARK GREY)	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Tested)		-		
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	Internal	Ground Floor	PREP ROOM	184868	VINYL FLOOR SHEETING (DARK GREY)	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Tested)		-		
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	Internal	Ground Floor	LAUNDRY	184861	SHEETING TO BASE - UNDER HOT WATER UNIT	Other (refer to description)	Cement Based	To be determined	3	Presumed	18	-		
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	Internal	Ground Floor	KITCHEN	184865	SHEET VINYL FLOOR COVERING DARK GREY IN COLOUR SIM TO SAMPLE 20747	Floor Finish/Covering	Vinyl Sheeting (includes backing)	Not determined	4	Removed	62	-		
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	Internal	Ground Floor	3-5 YEAR OLDS ACTIVITES AREA	184866	VINYL FLOOR SHEETING (DARK GREY)	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Tested)		-		
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	Internal	Ground Floor	2-3 YEAR OLDS ACTIVITIES AREA	184869	VINYL FLOOR SHEETING (DARK GREY)	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Tested)		-		
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	External	Ground Floor	VERANDAH	24717	CEILING SHEETING	Ceiling	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-		
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	External	Ground Floor	SOFFITS	24721	SOFFIT SHEETING - EASTERN ELEVATON	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-		
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	External	Ground Floor	SOFFITS	24720	SOFFIT SHEETING - SOUTHERN ELEVATION	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-		

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLLOONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	External	Ground Floor	FRONT ENTRY	24718	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLLOONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	Internal	Ground Floor	3-5 YEAR OLDS ACTIVITES AREA	184867	VINYL FLOOR SHEETING (LIGHT GREY)	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLLOONGABBA) (34E-E035) (20850000)	EARLY LEARNING CTR	34E-E035-002	20850001	Internal	Ground Floor	NURSERY SLEEP ROOM	412407	CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLLOONGABBA) (34E-E035) (20850000)	SHADE STRUCTURE	34E-E035-003	20850002	External	Whole Building (asbestos free)	SHADE STRUCTURE	363977	BUILDING CONSTRUCTED POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLLOONGABBA) (34E-E035) (20850000)	STORAGE SHED	34E-E035-004	20850003	External	Ground Floor	STORAGE SHED	24719	STRUCTURE CONSTRUCTED OF METAL	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	NAZARETH LUTHERAN EARLY LEARNING CENTRE (WOOLLOONGABBA) (34E-E035) (20850000)	STORAGE SHED	34E-E035-005	20850004	External	Ground Floor	STORAGE LOCKER	24716	STRUCTURE CONSTRUCTED OF TIMBER AND METAL	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	OAKLEIGH C&K COMM K/GARTEN	** Site - Grounds	53806000	53806000												-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	** Site - Grounds	34E-E060	21858000												-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	01 - SHED	34E-E060-001	21858001	External	Whole Building (asbestos free)	SHED	309046	STRUCTURE CONTAINS NO ASBESTOS CONTAINING MATERIAL - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	External	Ground Floor	WALKWAY	146129	REMOVED AS PER AUDIT 07/04/2011 - WALKWAY UNDER REFURBISHMENT - CEILING SHEETING	Ceiling	Cement Based	Not determined	4	Removed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	Internal	Ground Floor	UNIT 2	145835	REMOVED AS PER AUDIT 07/04/2011 - UNIT 2 UNDER REFURBISHMENT - CEILING SHEETING - STORE AND KITCHEN	Ceiling	Cement Based	Not determined	4	Removed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	Internal	Ground Floor	UNIT 2	145878	WALL SHEETING - ABOVE WINDOWS AND DOORS - VERANDAH	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	Internal	Ground Floor	UNIT 2	145978	REMOVED AS PER AUDIT 07/04/2011 - UNIT 2 UNDER REFURBISHMENT - CEILING SHEETING - VERANDAH	Ceiling	Cement Based	Not determined	4	Removed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	Internal	Ground Floor	UNIT 2	146007	REMOVED AS PER AUDIT 07/04/2011 - UNIT 2 UNDER REFURBISHMENT - CEILING SHEETING	Ceiling	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	Internal	Ground Floor	UNIT 1	308996	REMOVED AS PER AUDIT 07/04/2011 - UNIT 1 UNDER REFURBISHMENT - WALL SHEETING - STORE	Wall	Cement Based	Mixed	4	Removed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	Internal	Ground Floor	UNIT 2	145787	WALL SHEETING - ABOVE WINDOWS - STORE	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	Internal	Ground Floor	STUDENT TOILETS	145765	WALL PARTITIONS - TO TOILETS	Wall	Cement Based	To be determined	4	Presumed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	External	Ground Floor	VENT PIPES	146144	VENT PIPES (2) - BACK OF PRE-SCHOOL	Drains/Pipes/Flues	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	External	Ground Floor	SOFFIT	308999	REMOVED AS PER AUDIT 07/04/2011 - OFFICE UNDER REFURBISHMENT - SOFFIT SHEETING - TO OFFICE	Gable/Soffit/Fascia	Cement Based	Not determined	4	Removed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	External	Ground Floor	EXTERNAL WALLS	145866	REMOVED - ARP A110831 - WALL CLADDING - OFFICE BLOCK	Wall	Cement Based	CHR - Chrysotile	2	Removed	34	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	External	Ground Floor	EXTERNAL WALLS	308998	REMOVED - ARP A110831 - WALL SHEETING - BELOW WINDOWS - AT REAR OF SCHOOL	Wall	Cement Based	Not determined	4	Removed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	External	Ground Floor	BALUSTRADE	308997	METAL SHEETING TO BALUSTRADE - AT BACK STAIRS TO UNIT 1	Baffles/Lining	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	Internal	Ground Floor	STOREROOM	145739	REMOVED - VINYL FLOOR TILES	Floor	Vinyl Tiles	CHR - Chrysotile	4	Removed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	02 - TEACHING BLOCK	34E-E060-002	21858002	Internal	Ground Floor	OFFICE	145760	REMOVED AS PER AUDIT 07/04/2011 - OFFICE UNDER REFURBISHMENT - CEILING SHEETING	Ceiling	Cement Based	Not determined	4	Removed	18	-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	03 - SHADE COVER	34E-E060-003	21858004	External	Whole Building (asbestos free)	SHADE COVER	309047	STRUCTURE CONSTRUCTED POST 1990 - PRESUMED ASBEESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	THE GAP C&K COMMUNITY KINDERGARTEN	04 - COVERED AREA - SANDPIT	34E-E060-004	21858005	External	Whole Building (asbestos free)	SANDPIT STRUCTURE	309048	STRUCTURE CONSTRUCTED POST 1990 - PRESUMED ASBEESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
Metropolitan	DURACK C&K COMMUNITY KINDERGARTEN	** Site - Grounds	54374000	54374000												-	
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	** Site - Grounds	29333000	29333000												-	
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	03 - SHED - STORAGE	29333003	29333003												-	
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	05 - COVERED AREA - SANDPIT	29333004	29333004	External	Whole Building (asbestos free)	SAND PIT - SHADE COVER	315308	CONSTRUCTED 1990 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	02 - CENTRE	34E-E006-002	29333001	External	Ground Floor	FASCIA	62993	FASCIA SHEETING	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	02 - CENTRE	34E-E006-002	29333001	External	Ground Floor	SOFFITS & VERANDAH	315304	SOFFIT SHEETS	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	02 - CENTRE	34E-E006-002	29333001	Internal	Ground Floor	BANDICOOT STOREROOM	375833	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	02 - CENTRE	34E-E006-002	29333001	Internal	Ground Floor	KITCHEN, VARIOUS ROOMS, PASSAGEWAY	62914	VINYL FLOOR SHEETING	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	02 - CENTRE	34E-E006-002	29333001	Internal	Ground Floor	RECEPTION	315303	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	03 - LADY GOWRIE F D C	34E-E006-003	29333002	Internal	Ground Floor	FOYER & TOILET	315307	VINYL FLOOR SHEETING	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	03 - LADY GOWRIE F D C	34E-E006-003	29333002	External	Ground Floor	EXTERNAL WALLS	315305	WALL SHEETING	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	03 - LADY GOWRIE F D C	34E-E006-003	29333002	Internal	Ground Floor	VARIOUS ROOMS - STAFFROOM	315306	VINYL FLOOR SHEETING	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	03 - LADY GOWRIE F D C	34E-E006-003	29333002	External	Ground Floor	SOFFITS	62928	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	06 - SHADE STRUCTURE - SANDPIT	34E-E006-006	29333005	External	Whole Building (asbestos free)	COVERED SANDPIT	315309	CONSTRUCTED 1997 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	07 - COVERED AREA - PERGOLA	34E-E006-007	29333006	External	Whole Building (asbestos free)	PERGOLA	315310	CONSTRUCTED 1995 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	09 - SHED - STORAGE	34E-E006-009	29333011	External	Whole Building (asbestos free)	STORE SHED	315312	CONSTRUCTED 1998 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	10 - SHADE STRUCTURE	34E-E006-010	29333012	External	Whole Building (asbestos free)	SHADE STRUCTURE	315313	CONSTRUCTED 1999 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	11 - SHADE STRUCTURE	34E-E006-011	29333014	External	Whole Building (asbestos free)	SHADE STRUCTURE	315315	CONSTRUCTED 2000 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	12 - SHADE STRUCTURE	34E-E006-012	29333013	External	Whole Building (asbestos free)	SHADE STRUCTURE	315314	CONSTRUCTED 1999 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	TORRENS ROAD CHILD CARE CENTRE (CABOOLTURE) (34E-E006) (29333000)	08 - MEETING HALL	34E-E006-E008	29333010	External	Whole Building (asbestos free)	MEETING HALL	315311	CONSTRUCTED 2001 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	GROUNDS	34E-E008-001	23755000	External	Ground Floor	BLOCK RETAINING WALL - NORTHWEST CORNER OF MAIN BUILDING	375901	PROTECTION COVER FOR PVC STORMWATER OUTLET - COMPRESSED	Baffles/Lining	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	External	Roof Level 1	ROOF	29846	CORRUGATED ROOF SHEETING TO LOWER GROUND BUILDING & GARAGE, PHOTO 1/4	Roof Sheeting	Cement Based	Not determined	4	Removed	18	-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	External	Level 1	VERANDAH	29966	FLOOR - COMPRESSED SHEETING	Floor	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	Internal	Level 1	BATHROOM, LAUNDRY	375904	WALL SHEETING	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	Internal	Ground Floor	TOILET, BATHROOM, LAUNDRY	29816	WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	Internal	Ground Floor	STAIR SPANDRAL	375902	WALL SHEETING	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	Internal	Ground Floor	ALL FLOORS	29977	VINYL FLOORING	Floor	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	External	Ground Floor	DISCONNECT TRAP SURROUND - WESTERN SIDE	29971	DISCONNECT TRAP SURROUND FOR VENT - WEST ELEVATION	Stormwater Plumbing	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	External	Level 1	SOFFITS	29927	CEILING SHEETING - SOFFITS AND VERANDAH CEILINGS	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	External	Level 1	EXTERNAL SHEETING	29903	WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	External	Ground Floor	SOFFITS	29933	SOFFIT SHEETING AND VERANDAH CEILINGS	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	External	Ground Floor	OFFICE	29983	WALL SHEETING - HARDIPLANK TO OUTSIDE OF MAIN OFFICE	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	MAIN BUILDING	34E-E008-002	23755001	External	Roof Level 2	ROOF	29778	CORRUGATED ROOF SHEETING TO MAIN UPSTAIRS BUILDING ROOF	Roof Sheeting	Cement Based	Not determined	4	Removed	18	-	
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	COV PLAY AREA	34E-E008-003	23755003	External	Whole Building (asbestos free)	COVERED PLAY AREA	318728	CONSTRUCTED 1991 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	SHADE STRUCTURE	34E-E008-004	23755004	External	Whole Building (asbestos free)	SHADE STRUCTURE	318729	CONSTRUCTED 2001 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	STORE SHED	34E-E008-005	23755005	External	Whole Building (asbestos free)	STORE SHED	318733	CONSTRUCTED 2001 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	C&K CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E008) (23755000)	SHADE STRUCTURE	34E-E008-006	23755006	External	Whole Building (asbestos free)	SHADE STRUCTURE	318740	CONSTRUCTED 2002 - ASBESTOS FREE.	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	GROUNDS	34E-E009-001	30036000	External	Site / Grounds	SITE	76085	AUDIT ASBESTOS FREE	Wall	Other (refer to description)	Not Required	4	Not Present(Not Tested)		-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	SHED	34E-E009-002	30036001	External	Ground Floor	STORE SHED	65341	CONSTRUCTED 1989 - AUDIT ASBESTOS FREE	Wall	Other (refer to description)	Not Required	4	Not Present(Not Tested)		-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	Internal	Ground Floor	STAFF ROOM	375872	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	Internal	Ground Floor	TOILET & ENTRY ROOM - YEARS 1 TO 5	375863	WALL SHEETING	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	Internal	Ground Floor	TOILET & ENTRY ROOM - YEARS 1 TO 5	375865	CEILING	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	Internal	Ground Floor	STORE ROOM - YEARS 1 TO 5	375869	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	Internal	Ground Floor	SLEEP ROOM	375861	WALL PANELS ABOVE WINDOWS & DOORS BETWEEN ROOF PURLINS	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	Internal	Ground Floor	STAFF ROOM	375873	WALL SHEETING TO LINTAL BEAM	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	Internal	Ground Floor	PASSAGEWAY & MAIN ENTRANCE	318681	VINYL FLOOR SHEETING	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	5	Not Present(Not Tested)		-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	Internal	Ground Floor	SLEEP ROOM	375854	CEILING SHEETING	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	Internal	Ground Floor	INTERNAL	65422	INTERNAL CEILING SHEETS THROUGHOUT IS GYROCK	Ceiling	Cement Based	Not determined	5	Removed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	Internal	Ground Floor	ACTIVITIES, STORE ROOM & LAUNDRY	318680	VINYL FLOOR SHEETING	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	External	Ground Floor	SOFFIT	318679	SOFFITS & VERANDAH CEILINGS	Gable/Soffit/Fascia	Cement Based	To be determined	5	Presumed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	External	Ground Floor	EXTERNAL	375899	WALL SHEETING TO TOILET BLOCK & ENTRY, YEARS 1 TO 5, NORTH ELEVATION	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	External	Ground Floor	EXTERNAL	318682	WALL SHEETING TO GABLE ENDS	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	CENTRE	34E-E009-003	30036002	Internal	Ground Floor	STORE ROOM - YEARS 1 TO 5	375868	WALL SHEETING	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	SHADE STRUCTURE	34E-E009-004	30036003	External	Whole Building (asbestos free)	SHADE STRUCTURE	318683	CONSTRUCTED 2000 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	SHADE STRUCTURE	34E-E009-005	30036004	External	Whole Building (asbestos free)	SHADE STRUCTURE	318684	CONSTRUCTED 2001 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	SHADE STRUCTURE	34E-E009-006	30036005	External	Whole Building (asbestos free)	SHADE STRUCTURE	318685	CONSTRUCTED 2001 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	SHADE STRUCTURE	34E-E009-007	30036006	External	Whole Building (asbestos free)	SHADE STRUCTURE	318686	CONSTRUCTED 2001 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Coast	C&K NORTH CALOUNDRA COMMUNITY CHILDCARE CENTRE (34E-E009) (30036)	SHADE SAILS STRUCT	34E-E009-008	30036007	External	Whole Building (asbestos free)	SHADE SAIL STRUCTURE	318687	CONSTRUCTED 2002 - ASBESTOS FREE	Wall	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	00 - KINDERGARTEN GROUNDS	34T-0379-000	22285000												-	
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	12 - KINDERGARTEN - UNIT 2	34T-0379-012	22285001	Internal	Ground Floor	INTERNAL	418640	COMPRESSED SHEETING TO FLOOR OF BATHROOM UNIT A	Floor	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	12 - KINDERGARTEN - UNIT 2	34T-0379-012	22285001	External	Ground Floor	EXTERNAL	431027	SOFFIT SHEETING CONTINUOUS ALL ELEVATIONS	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	SOFFITS AND CEILING OVER ENTRY
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	12 - KINDERGARTEN - UNIT 2	34T-0379-012	22285001	External	Ground Floor	EXTERNAL	163052	SHEETING TO SURROUND DT EASTERN SIDE	Drains/Pipes/Flues	Cement Based	To be determined	3	Presumed	18	-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	12 - KINDERGARTEN - UNIT 2	34T-0379-012	22285001	External	Ground Floor	EXTERNAL	163134	WALL SHEETING TO ABOVE DOORS (NORTH ELEVATION)	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	12 - KINDERGARTEN - UNIT 2	34T-0379-012	22285001	External	Ground Floor	EXTERNAL	163262	WALL SHEETING (SOUTH ELEVATION)	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	12 - KINDERGARTEN - UNIT 2	34T-0379-012	22285001	Internal	Ground Floor	INTERNAL	163201	WALL SHEETING TO BEHIND KITCHEN SINK AND WING WALL OPPOSITE KITCHEN SINK	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	12 - KINDERGARTEN - UNIT 2	34T-0379-012	22285001	Internal	Ground Floor	INTERNAL	418637	COMPRESSED SHEETING - FLOOR OF BATHROOM UNIT B	Floor	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	15 - KINDERGARTEN - UNIT 1	34T-0379-015	22285002	Internal	Ground Floor	OFFICE	431022	VINYL TILES TO SOUTH WEST CORNER	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	2	Confirmed	43	-	
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	15 - KINDERGARTEN - UNIT 1	34T-0379-015	22285002	Internal	Ground Floor	INTERNAL	494506	COMPRESSED FLOOR SHEETING	Floor	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	15 - KINDERGARTEN - UNIT 1	34T-0379-015	22285002	External	Ground Floor	EXTERNAL	163157	SOFFIT SHEETING	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	BWGCOLMAN COMMUNITY KINDERGARTEN/PRE (34T-0379) (22285)	26 - KINDERGARTEN - COVERED PLAY AREA	34T-0379-26	22285003												-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	GROUNDS	34E-E014-001	25128000												-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	ECEC	34E-E014-002	25128001	External	Ground Floor	EXTERNAL - GF	41937	WALL SHEET - BETWEEN ROOF AND BLOCK WALL	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	ECEC	34E-E014-002	25128001	Internal	Ground Floor	PREP ROOM AND AMENITIES	41925	WALL SHEETING - PREP ROOM AND AMENITIES	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	ECEC	34E-E014-002	25128001	Internal	Ground Floor	LAUNDRY	41898	CEILING (VILLABOARD) SHEETING - LAUNDRY	Ceiling	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	ECEC	34E-E014-002	25128001	Internal	Ground Floor	CHANGE ROOM	41840	WALL SHEETING - PARTITIONS END OF BENCH IN NURSEY CHANGE ROOM	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	ECEC	34E-E014-002	25128001	External	Site / Grounds	DUPLICATE ENTRY - EXTERNAL									-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	ECEC	34E-E014-002	25128001	External	Ground Floor	EXTERNAL - GF	41896	WALL SHEETING - BACK ENTRANCE AREA AND UNDER WINDOWS OF NURSERY CHANGE ROOM	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	ECEC	34E-E014-002	25128001	External	Ground Floor	EXTERNAL - GF	42050	WALL SHEETING - GABLE ENDS	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	ECEC	34E-E014-002	25128001	External	Ground Floor	EXTERNAL - GF	41992	COMPRESSED SHEETING TO SIGN IN FRONT YARD	Sign	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	ECEC	34E-E014-002	25128001	External	Ground Floor	EXTERNAL - GF	41983	WALL SHEETING - ARCHWAY FRONT ENTRANCE	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	ECEC	34E-E014-002	25128001	External	Ground Floor	EXTERNAL - GF	360619	WALL (VILLABOARD) SHEETING - LAUNDRY	Wall	Cement Based	Not Required	NA	Not Present(Not Tested)		-	Reinput record as was accidentally deleted - ACM was previously tested and not found to be asbestos.
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	ECEC	34E-E014-002	25128001	External	Site / Grounds	DUPLICATE ENTRY - FRONT YARD									-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	STORAGE SHED	34E-E014-003	25128002			---									-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	STORAGE SHED	34E-E014-003	25128002	External	Whole Building (asbestos free)	STORAGE SHED	41963	NO ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	PLAY EQUIPMENT AND SHED	34E-E014-004	25128003			---									-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	PLAY EQUIPMENT AND SHED	34E-E014-004	25128003	External	Whole Building (asbestos free)	PLAY EQUIPMENT AND SHED	41858	NO ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	LOG SHADE AREA 1	34E-E014-005	25128004												-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	LOG SHADE AREA 2	34E-E014-006	25128005												-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	LOG SHADE AREA 3	34E-E014-007	25128006												-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	SHADE STRUCTURE 1	34E-E014-008	25128007												-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	SHADE STRUCTURE 2	34E-E014-009	25128008												-	
North Queensland	KIRWAN UNITING CHURCH CHILDCARE CENTRE (34E-E014) (25128000)	COVERED AREA 1	34E-E014-010	25128009												-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	TOWNSVILLE COMMUNITY SPECIAL SCHOOL	34S-2376	22280000													-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	Internal	Ground Floor	STORE ROOM NEAR SICK ROOM	454447	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	Internal	Ground Floor	ENTRY NEAR REAR DOOR	454451	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	Internal	Ground Floor	INTERNAL - GF	184585	PERFORATED CEILING SHEETING - ADMINISTRATION BLOCK A	Ceiling	Cement Based	To be determined	3	Presumed	18		-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	Internal	Ground Floor	INTERNAL - GF	184586	COMPRESSED WALL SHEETING - AMENITIES CUBICLE PARTITION MALE, FEMALE AND DISABLED AMENITIES	Wall	Cement Based	To be determined	4	Presumed	18		-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	Internal	Ground Floor	NEAR HOT WATER SYSTEM	454457	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	EXTERNAL - GF	163053	SOFFIT SHEETING - ADMINISTRATION	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	Internal	Ground Floor	STORE ROOM	454453	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	Internal	Ground Floor	DOORWAY NEAR STAFF ROOM	454455	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	Internal	Ground Floor	SWITCHBOARD ROOM	184587	VINYL FLOOR SHEETING - SWITCHBOARD ROOM	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	3	Not Present(Tested)			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	Internal	Ground Floor	STAFF ROOM	454454	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	DOWNPIPES	188382	DOWNPIPE B	Stormwater Plumbing	Cement Based	Mixed		Removed			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	Internal	Ground Floor	HALLWAY	454449	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	DOWNPIPES	188381	DOWNPIPE A	Stormwater Plumbing	Cement Based	Mixed		Removed			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	EXTERNAL - GF	163130	FASCIA SHEETING - ADMINISTRATION	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	DOWNPIPES	188383	DOWNPIPE C	Stormwater Plumbing	Cement Based	Mixed		Removed			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	DOWNPIPES	188384	DOWNPIPE D	Stormwater Plumbing	Cement Based	Mixed		Removed			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	DOWNPIPES	188385	DOWNPIPE E	Stormwater Plumbing	Cement Based	Mixed		Removed			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	DOWNPIPES	188387	DOWNPIPE G	Stormwater Plumbing	Cement Based	Mixed		Removed			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	DOWNPIPES	188388	DOWNPIPE H	Stormwater Plumbing	Cement Based	Mixed		Removed			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	EXTERNAL - GF	163281	COMPRESSED SHEETING - ID SIGNS EASTERN AND WESTERN SIDES	Sign	Cement Based	To be determined	4	Presumed	18		-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	EXTERNAL - GF	163229	FIBREGLASS RAINWATER HEADS AND PIPES - ADMINISTRATION	Drains/Pipes/Flues	Cement Based	CHR - Chrysotile	4	Confirmed	18		-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	01 - ADMINISTRATION BLOCK A	34S-2376-001	22280002	External	Ground Floor	DOWNPIPES	188386	DOWNPIPE F	Stormwater Plumbing	Cement Based	Mixed		Removed			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	03 - MEETING BLOCK F	34S-2376-003	22280009													-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	04 - CLASSROOMS BLOCK G	34S-2376-004	22280010													-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	05 - CLASSROOMS BLOCK H	34S-2376-005	22280011													-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	07 - MODULAR BLOCK I	34S-2376-007	22280012	Internal	Other (refer to description)	DUPLICATE ENTRY - SOFFITS TO INTERNAL CEILINGS										-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	07 - MODULAR BLOCK I	34S-2376-007	22280012	Internal	Ground Floor	INTERNAL - GF	376082	CEILING SHEETING - STRAW PANELS	Ceiling	Other (refer to description)	Not Required	NA	Not Present(Not Tested)			-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	07 - MODULAR BLOCK I	34S-2376-007	22280012	External	Ground Floor	EXTERNAL - GF	376081	SOFFIT SHEETING - MODULAR BLOCK I	Ceiling	Cement Based	To be determined	4	Presumed	18		-
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	07 - MODULAR BLOCK I	34S-2376-007	22280012	External	Ground Floor	DUPLICATE ENTRY - SOFFITS TO EXTERNAL CEILINGS										-

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	07 - MODULAR BLOCK I	34S-2376-007	22280012	External	Ground Floor	EXTERNAL - GF	184596	WALL SHEETING - WESTERN SIDE	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	08 - BLOCK J - PREP	34S-2376-008	22280024	External	Ground Floor	EXTERNAL - GF	161447	COMPRESSED SHEETING - SCHOOL ID SIGN NORTHERN SIDE	Sign	Cement Based	Not determined	4	Removed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	08 - BLOCK J - PREP	34S-2376-008	22280024	Internal	Ground Floor	STAFF AMENITIES	161409	WALL SHEETING - STAFF AMENITIES	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	08 - BLOCK J - PREP	34S-2376-008	22280024	Internal	Ground Floor	WAITING AREA NORTHERN SIDE	161478	CEILING SHEETING - WAITING AREA NORTHERN SIDE	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	08 - BLOCK J - PREP	34S-2376-008	22280024	External	Ground Floor	EXTERNAL - GF	161416	COMPRESSED SHEETING - PANEL BETWEEN UNDER SIDE OF SOFFITT AND ROOF OF COVERED AREAS SOUTHERN SIDE	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	08 - BLOCK J - PREP	34S-2376-008	22280024	External	Ground Floor	EXTERNAL - GF	161370	SOFFITT SHEETING - BLOCK J	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	08 - BLOCK J - PREP	34S-2376-008	22280024	Internal	Ground Floor	CHILDREN'S AMENITIES	161250	COMPRESSED SHEETING - CHILDREN AMENITIES PARTITIONS	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	08 - BLOCK J - PREP	34S-2376-008	22280024	Internal	Ground Floor	INTERNAL - GF	161366	VINYL FLOOR SHEETING - TEACHING AREAS, TOILETS, OFFICE AND KITCHEN AREA	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Confirmed	62	-	SAME VINYL IS USED THROUGHOUT THESE AREAS
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	09 - STORE SHED	34S-2376-009	22280015			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	09 - STORE SHED	34S-2376-009	22280015	External	Whole Building (asbestos free)	STORE SHED	349527	STORE SHED - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	Internal	Ground Floor	ROOM D5	457818	PERFORATED CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	EXTERNAL - GF	163277	COMPRESSED SHEET TO PANELS ON BOTTOM OF SECURITY DOORS (PANELS UNPAINTED) -CVRD WITH PLY, ONLY 4SQM	Wall	Cement Based	Not determined	4	Removed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	Internal	Ground Floor	INTERNAL - GF	184589	PERFORATED CEILING SHEETING - STORE ROOMS AND HALLWAY	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	Internal	Ground Floor	ROOM D1 AND D2	457780	PERFORATED CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	EXTERNAL - GF	162965	COMPRESSED SHEETING - BUILDING ID SIGN WESTERN SIDE	Sign	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	Internal	Ground Floor	ROOM D4	457825	PERFORATED CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	EXTERNAL - GF	162881	SOFFIT SHEETING - TEACHING BLOCK D	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	Internal	Ground Floor	ROOMS ON NORTH SIDE	454404	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	Internal	Ground Floor	ROOMS ON SOUTH SIDE	454403	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	Internal	Ground Floor	ROOM D3	457810	PERFORATED CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	DOWNPIPES	188392	DOWNPIPE D	Stormwater Plumbing	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	Internal	Ground Floor	INTERNAL - GF	184588	VINYL FLOOR SHEETING - ROOMS AND HALLWAY	Floor Finish/Covering	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	EXTERNAL - GF	162951	PARAPET SHEETING - TEACHING BLOCK D	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	DOWNPIPES	188391	DOWNPIPE C	Stormwater Plumbing	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	DOWNPIPES	188389	DOWNPIPE A	Stormwater Plumbing	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	DOWNPIPES	188393	DOWNPIPE E	Stormwater Plumbing	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	DOWNPIPES	188394	DOWNPIPE F	Stormwater Plumbing	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	DOWNPIPES	188395	DOWNPIPE G	Stormwater Plumbing	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	DOWNPIPES	188396	DOWNPIPE H	Stormwater Plumbing	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	DOWNPIPES	188397	DOWNPIPE I	Stormwater Plumbing	Other (refer to description)	No asbestos detected (NAD)		Removed		-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	EXTERNAL - GF	163182	RAINWATER HEADS AND DOWNPIPES - NORTHERN AND SOUTHERN SIDES	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	10 - TEACHING BLOCK D	34S-2376-010	22280003	External	Ground Floor	DOWNPIPES	188390	DOWNPIPE B	Stormwater Plumbing	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	Internal	Ground Floor	ROOMS ON SOUTH SIDE	454413	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	EXTERNAL - GF	161960	PARAPET SHEETING - TEACHING BLOCK E	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	Internal	Ground Floor	INTERNAL - GF	163125	PERFORATED CEILING SHEETING - HALLWAY AND STORE ROOMS	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	Internal	Ground Floor	INTERNAL - GF	163002	VINYL FLOOR SHEETING - HALLWAY	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	3	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	Internal	Ground Floor	ROOM E1 AND E2	457541	PERFORATED CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	Internal	Ground Floor	ROOM E3	457561	PERFORATED CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	DOWNPIPES	187901	EXTERNAL DOWNPIPE C	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	Internal	Ground Floor	ROOM E4	457563	PERFORATED CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	Internal	Ground Floor	ROOM E5	457557	PERFORATED CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	EXTERNAL - GF	163074	FIBREGLASS RAINWATER HEADS AND DOWNPIPES - TEACHING BLOCK E	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	Internal	Ground Floor	ROOMS ON NORTH SIDE	454414	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	DOWNPIPES	187898	EXTERNAL DOWNPIPE F	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	DOWNPIPES	187903	EXTERNAL DOWNPIPE E	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	EXTERNAL - GF	162931	COMPRESSED SHEET TO PANELS ON BOTTOM OF SECURITY DOORS (PANELS UNPAINTED)	Wall	Cement Based	Not determined	4	Removed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	DOWNPIPES	187899	EXTERNAL DOWNPIPE A	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	DOWNPIPES	187900	EXTERNAL DOWNPIPE B	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	DOWNPIPES	187902	EXTERNAL DOWNPIPE D	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	DOWNPIPES	187904	EXTERNAL DOWNPIPE G	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	DOWNPIPES	187905	EXTERNAL DOWNPIPE H	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	DOWNPIPES	187906	EXTERNAL DOWNPIPE I	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)		Removed		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	11 - TEACHING BLOCK E	34S-2376-011	22280001	External	Ground Floor	EXTERNAL - GF	162953	COMPRESSED SHEETING - BUILDING ID SIGN WESTERN SIDE	Sign	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	12 - BLOCK D AND BLOCK C SHADE SAILS	34S-2376-012	22280016	External	Whole Building (asbestos free)	SHADE SAILS	349528	BLOCK D AND BLOCK C SHADE SAILS - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	12 - BLOCK D AND BLOCK C SHADE SAILS	34S-2376-012	22280016			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	13 - BLOCK D AND BLOCK E SHADE SAILS	34S-2376-013	22280017			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	13 - BLOCK D AND BLOCK E SHADE SAILS	34S-2376-013	22280017	External	Whole Building (asbestos free)	SHADE SAILS	349529	BLOCK D AND BLOCK E SHADE SAILS - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	14 - MULTI PURPOSE BLOCK B	34S-2376-014	22280005	External	Ground Floor	EXTERNAL - GF	162969	COMPRESSED WALL SHEETING - BOTTOM PANELS IN SECURITY DOORS	Wall	Cement Based	To be determined	4	Presumed	18	-	(PANELS UNPAINTED)
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	14 - MULTI PURPOSE BLOCK B	34S-2376-014	22280005	External	Ground Floor	EXTERNAL - GF	163046	RAINWATER HEADS AND DOWNPIPES - NORTHERN AND SOUTHERN SIDES	Drains/Pipes/Flues	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	14 - MULTI PURPOSE BLOCK B	34S-2376-014	22280005	Internal	Ground Floor	INTERNAL - GF	184595	CEILING SHEETING - ACTIVITIES AREA ABOVE OPEN TRUSSES	Ceiling	Cement Based	To be determined	4	Presumed	18	-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	14 - MULTI PURPOSE BLOCK B	34S-2376-014	22280005	Internal	Ground Floor	INTERNAL - GF	184594	VINYL FLOOR SHEETING - STORE ROOM WESTERN SIDE	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	3	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	14 - MULTI PURPOSE BLOCK B	34S-2376-014	22280005	Internal	Ground Floor	INTERNAL - GF	184593	VINYL FLOOR SHEETING - STORE ROOMS EASTERN SIDE	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	14 - MULTI PURPOSE BLOCK B	34S-2376-014	22280005	External	Ground Floor	EXTERNAL - GF	163113	SOFFIT SHEETING - MULTI PURPOSE BLOCK B	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	14 - MULTI PURPOSE BLOCK B	34S-2376-014	22280005	External	Ground Floor	EXTERNAL - GF	163218	COMPRESSED SHEETING - BUILDING ID SIGN EASTERN SIDE	Sign	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	14 - MULTI PURPOSE BLOCK B	34S-2376-014	22280005	External	Ground Floor	EXTERNAL - GF	162967	FASCIA SHEETING - MULTI PURPOSE BLOCK B	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	14 - MULTI PURPOSE BLOCK B	34S-2376-014	22280005	External	Ground Floor	EXTERNAL - GF	163075	CEILING SHEETING - WALKWAY ADJOINING MULTI PURPOSE BLOCK B TO COVERED WALKWAY	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	16 - SHADE STRUCTURE	34S-2376-016	22280014			---										
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	16 - SHADE STRUCTURE	34S-2376-016	22280014	External	Whole Building (asbestos free)	SHADE STRUCTURE	349526	SHADE STRUCTURE - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	18 - SWIMMING POOL	34S-2376-018	22280008	External	Other (refer to description)	DUPLICATE ENTRY - N/A									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	18 - SWIMMING POOL	34S-2376-018	22280008	External	Other (refer to description)	SWIMMING POOL	179737	SWIMMING POOL - NO ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	20 - LAUNDRY/JANITOR/STORE ROOM BLOCK C	34S-2376-020	22280004	Internal	Ground Floor	CLEANER'S ROOM	454396	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	20 - LAUNDRY/JANITOR/STORE ROOM BLOCK C	34S-2376-020	22280004	Internal	Ground Floor	LUNCH ROOM	454395	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	20 - LAUNDRY/JANITOR/STORE ROOM BLOCK C	34S-2376-020	22280004	Internal	Ground Floor	STORE ROOM WEST END	184592	VINYL FLOOR SHEETING - STORE ROOM WEST END	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	20 - LAUNDRY/JANITOR/STORE ROOM BLOCK C	34S-2376-020	22280004	Internal	Ground Floor	INTERNAL - GF	184591	CEILING SHEETING - BREEZEWAY OUTSIDE JANITORS WORK ROOM	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	20 - LAUNDRY/JANITOR/STORE ROOM BLOCK C	34S-2376-020	22280004	Internal	Ground Floor	INTERNAL - GF	184590	COMPRESSED WALL SHEETING - STAFF AMENITIES AND STAFF WASH ROOM PARTITION WALLS	Wall	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	20 - LAUNDRY/JANITOR/STORE ROOM BLOCK C	34S-2376-020	22280004	External	Ground Floor	EXTERNAL - GF	163004	RAINWATER HEADS AND DOWNPIPES - NORTHERN AND SOUTHERN SIDES	Drains/Pipes/Flues	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	20 - LAUNDRY/JANITOR/STORE ROOM BLOCK C	34S-2376-020	22280004	External	Ground Floor	EXTERNAL - GF	162929	FASCIA SHEETING - BLOCK C	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	20 - LAUNDRY/JANITOR/STORE ROOM BLOCK C	34S-2376-020	22280004	Internal	Ground Floor	WORKSHOP	454394	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	20 - LAUNDRY/JANITOR/STORE ROOM BLOCK C	34S-2376-020	22280004	External	Ground Floor	EXTERNAL - GF	163214	COMPRESSED SHEETING - BUILDING ID SIGN WESTERN SIDE	Sign	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	20 - LAUNDRY/JANITOR/STORE ROOM BLOCK C	34S-2376-020	22280004	External	Ground Floor	EXTERNAL - GF	163078	SOFFIT SHEETING - BLOCK C	Gable/Soffit/Fascia	Cement Based	To be determined	4	Presumed	18	-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	20 - LAUNDRY/JANITOR/STORE ROOM BLOCK C	34S-2376-020	22280004	Internal	Ground Floor	CHANGE ROOM	454397	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	21 - COVERED AREA	34S-2376-021	22280006	External	Ground Floor	COVERED WAY	163096	WALL SHEETING - GABLE ENDS NORTHERN AND SOUTHERN SIDES	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	22 - COVERED SET DOWN AREA	34S-2376-022	22280007	External	Ground Floor	COVERED SET DOWN AREA	163250	WALL SHEETING - GABLE ENDS EASTERN AND WESTERN SIDES	Wall	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Tested)		-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	23 - GARDEN SHED	34S-2376-023	22280013												-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	24 - SHADE PLAY EQUIPMENT 1	34S-2376-024	22280018			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	24 - SHADE PLAY EQUIPMENT 1	34S-2376-024	22280018	External	Whole Building (asbestos free)	SHADE PLAY EQUIPMENT 1	349530	SHADE PLAY EQUIPMENT 1 - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	25 - COVERED STRUCTURE	34S-2376-025	22280019	External	Whole Building (asbestos free)	COVERED STRUCTURE	349531	COVERED STRUCTURE - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	25 - COVERED STRUCTURE	34S-2376-025	22280019			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	26 - GARDEN SHED	34S-2376-026	22280020			---									-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	26 - GARDEN SHED	34S-2376-026	22280020	External	Whole Building (asbestos free)	GARDEN SHED	349532	GARDEN SHED - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	27 - SHADE PLAY EQUIPMENT 2	34S-2376-027	22280021			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	27 - SHADE PLAY EQUIPMENT 2	34S-2376-027	22280021	External	Whole Building (asbestos free)	SHADE PLAY EQUIPMENT 2	349533	SHADE PLAY EQUIPMENT 2 - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	28 - SHADE SAIL	34S-2376-028	22280022			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	28 - SHADE SAIL	34S-2376-028	22280022	External	Whole Building (asbestos free)	SHADE SAIL	349534	SHADE SAIL - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	29 - COVERED AREA	34S-2376-029	22280023			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	29 - COVERED AREA	34S-2376-029	22280023	External	Whole Building (asbestos free)	COVERED AREA	349535	COVERED AREA - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	30 - GARDEN SHED BLOCK J	34S-2376-030	22280025			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	31 - SHADED SAND PIT BLOCK J	34S-2376-031	22280026			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	32 - SHADED SEATING BLOCK J	34S-2376-032	22280027			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	34 - SENIOR SHADE	34S-2376-034	22280029			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	34 - SENIOR SHADE	34S-2376-034	22280029	External	Whole Building (asbestos free)	SENIOR SHADE	349524	SENIOR SHADE - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	35 - SENIOR PLAYGROUND	34S-2376-035	22280030			---									-	
North Queensland	TOWNSVILLE COMMUNITY LEARNING CENTRE (34S-2376) (22280)	35 - SENIOR PLAYGROUND	34S-2376-035	22280030	External	Whole Building (asbestos free)	SENIOR PLAYGROUND	349525	SENIOR PLAYGROUND - BUILT POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	GROUNDS	34E-E001-001	21744000	External	Ground Floor	GROUNDS	356423	SIGN - LAYING ON GROUND BESIDE FRONT DOUBLE GATES	Sign	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	STAFF AMENITIES	142674	WALL SHEETING - STAFF TOILET	Wall	Cement Based	Not determined	4	Removed	18	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	DUPLICATE ENTRY - EXTERNAL STORAGE ROOM									-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	STAFF AMENITIES AND STORE ROOM	142445	VINYL FLOOR SHEETING - STORE ROOM AND TOILET	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Removed	62	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	DUPLICATE ENTRY - MAIN BLDG FLOOR									-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	DUPLICATE ENTRY - SLIDING DOORS									-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	INTERNAL - GF	142641	WALL SHEETNG - HALLWAY, KITCHEN AND PARTITIONS	Wall	Cement Based	Not determined	4	Removed	18	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	INTERNAL - GF	142653	CEILING SHEETNG - UNIT 1	Ceiling	Cement Based	Not determined	4	Removed	18	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	INTERNAL - GF	142830	VINYL FLOOR SHEETING - DESK AREA	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Removed	62	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	PARTITION WALLS									-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	CHILDRENS AMENITIES	142757	SHEET VINYL FLOOR COVER TO FLOOR AREA OF CHILDRENS TOILET	Floor	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Removed	62	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	KITCHEN	142816	VINYL FLOOR SHEETING - KITCHEN	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Removed	62	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	External	Ground Floor	DUPLICATE ENTRY - EXT. GABLE ENDS									-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	CHILDRENS AMENITIES	142652	WALL SHEETNG - BEHIND TOILET CISTERNS	Wall	Cement Based	Not determined	4	Removed	18	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	DUPLICATE ENTRY - CHILDRENS TOILT									-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	External	Ground Floor	DUPLICATE ENTRY - SCHOOL SIGN									-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	External	Ground Floor	EXTERNAL - GF	142648	SOFFIT SHEETING - UNIT 1	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Removed	18	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	External	Ground Floor	EXTERNAL - GF	142611	WALL SHEETING - FRONT AND REAR GABLE ENDS	Wall	Cement Based	Not determined	4	Removed	18	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	External	Ground Floor	EXTERNAL - GF	142599	COMPRESSED SHEET SIGN AT MAIN DOOR FACING ROAD - WEST END	Sign	Cement Based	CHR - Chrysotile	4	Removed	18	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	External	Ground Floor	EXTERNAL - GF	142899	CEILING SHEETING - EXTERNAL STORE ROOM EAST SIDE	Ceiling	Cement Based	Not determined	4	Removed	18	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	External	Ground Floor	EXTERNAL - GF	142732	WALL SHEETING - SLIDING DOORS NORTH SIDE AND PANELS	Wall	Cement Based	Not determined	4	Removed	18	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	COMMUNITY ECEC	34E-E001-002	21744001	Internal	Ground Floor	CHILDRENS AMENITIES	142739	WALL SHEETING - AMENITIES CUBICLE PARTITIONS	Wall	Cement Based	Not determined	4	Removed	18	-	
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	SHED - STORE	34E-E001-005	21744005	External	Whole Building (asbestos free)	SHED - STORE	430914	BUILDING CONSTRUCTED POST 1990 ÔÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	SHED - STORE	34E-E001-006	21744006	External	Whole Building (asbestos free)	SHED - STORE	430913	BUILDING CONSTRUCTED POST 1990 ÔÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	SHADE STRUCTURE	34E-E001-007	21744007	External	Whole Building (asbestos free)	SHADE STRUCTURE	430912	BUILDING CONSTRUCTED POST 1990 ÔÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
North Queensland	AYR COMMUNITY KINDERGARTEN (34E-E001) (21744000)	SHADE STRUCTURE	34E-E001-008	21744008	External	Whole Building (asbestos free)	SHADE STRUCTURE	430911	BUILDING CONSTRUCTED POST 1990 ÔÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	GROUNDS	34E-E021-001	21424000		Site / Grounds	MARTIN ST FENCE	179833	SHEET WITH PRE-SCHOOL SIGN - PHOTO 1/14 - SIM SAMPLE #SC0878	Sign	Cement Based	Not determined	4	Removed	18	-	
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	ECEC EYC	34E-E021-002	21424001		Ground Floor	TOILET	130311	CS SHEETS TO TOILET PARTITIONS SAMPLE #SC0878	Wall	Cement Based	CHR - Chrysotile	4	Removed	18	-	
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	ECEC EYC	34E-E021-002	21424001		Site / Grounds	SOUTH	130162	TELECOM BOX IN GROUND FRONT MAIN ENTRY NEAR CONCRETE DRAIN - SIM SAMPLE #SC0876 -PHOTO 1/5	Preformed Moulded Product	Cement Based	Not determined	4	Removed	18	-	
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	ECEC EYC	34E-E021-002	21424001	External	Roof Level 2	MAIN ENTRY	130212	CEILING SHEETING - SOUTH ELEVATION	Ceiling	Cement Based	To be determined	4	Presumed	18	-	
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	ECEC EYC	34E-E021-002	21424001	External	Roof Level 1	SOFFIT	129959	CEILING SHEETING - NORTH ELEVATION	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	ECEC EYC	34E-E021-002	21424001		Ground Floor	EAST	130229	CORRUGATED SHEETING TO HOOD ABOVE WINDOWS SIM TO SAMPLE #SC0877	Sun Hood	Cement Based	Not determined	4	Removed	18	-	
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	ECEC EYC	34E-E021-002	21424001		Ground Floor	SOUTH	130044	MOULDS AROUND BOTTOM OF DOWNPIPES - PHOTO 1/4 - SIM SAMPLE #SC0876	Drains/Pipes/Flues	Cement Based	Not determined	4	Removed	18	-	
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	ECEC EYC	34E-E021-002	21424001		Ground Floor	NORTH	130213	MOULDS AROUND BOTTOM OF DOWNPIPE & VENT GRATE - PHOTO 1/3 - SIM SAMPLE #SC0876	Drains/Pipes/Flues	Cement Based	Mixed	4	Removed	18	-	
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	ECEC EYC	34E-E021-002	21424001	External	Ground Floor	WEST	130103	CORRUGATED SHEETING TO HOOD ABOVE WINDOWS SAMPLE #SC0877	Sun Hood	Cement Based	Mixed	4	Removed	18	-	
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	STORAGE SHED	34E-E021-005	21424010	External	Whole Building (asbestos free)	STORAGE SHED	465899	BUILDING CONSTRUCTED POST 1990 ÔÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	06 - STORAGE SHED	34E-E021-006	21424005	External	Whole Building (asbestos free)	STORAGE SHED	465898	BUILDING CONSTRUCTED POST 1990 ÔÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	07 - PLAY SHADE SAIL	34E-E021-007	21424006	External	Whole Building (asbestos free)	PLAY SHADE SAIL	465901	BUILDING CONSTRUCTED 2009 ÔÇö ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
South East	THE BENEVOLENT SOCIETY - NORTH GOLD COAST EARLY YEARS CENTRE (NERANG) (34E-E021) (21424000)	SHADE STRUCTURE	34E-E021-008	21424011	External	Whole Building (asbestos free)	SHADE STRUCTURE	430915	BUILDING CONSTRUCTED POST 1990 ÔÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)	-	-	Building built post 1990
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	GROUNDS	34E-E004-001	20655000		Ground Floor	EXTERNAL	179956	METAL SHED PHOTO 1/4 ASBESTOS FREE MATERIAL	Wall		Not required	4	Removed	-	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	GROUNDS	34E-E004-001	20655000		Site / Grounds	FRONT FENCE	179884	CS PRE-SCHOOL SIGN PHOTO 1/3 SIMILAR TO SAMPLE #SC2360	Sign	Cement Based	Not determined	4	Removed	18	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	FOYER	104898	SHEET VINYL SAMPLES #SC2358 / SC9413	Floor	Other (refer to description)	No asbestos detected (NAD)	4	Removed	-	-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	UNIT NO. 2	104557	PLASTER SHEETING ASBESTOS FREE MATERIAL	Ceiling	Other (refer to description)	Not required	4	Removed		-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	UNIT NO. 1	104880	PLASTER SHEETING ASBESTOS FREE MATERIAL	Ceiling	Other (refer to description)	Not required	4	Removed		-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	UNIT NO. 1	104899	PLASTER SHEETING ASBESTOS FREE MATERIAL	Wall	Other (refer to description)	Not required	4	Removed		-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	STAFF TOILET	104742	AC ABOVE TOILET PEDESTAL AREA SAMPLE #SC2359	Ceiling	Cement Based	CHR - Chrysotile	4	Removed	18	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	UNIT 2 TOILET	104754	CS TOILET PARTITIONS SAMPLE #SC2361	Wall	Cement Based	CHR - Chrysotile	4	Removed	18	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	WEST EXTERNAL	104606	AC PANEL ABOVE & BELOW WINDOWS SIMILAR TO SAMPLE #SC2356	Wall	Cement Based	Not determined	4	Removed	18	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	UNIT 1 TOILET	104543	CS TOILET PARTITIONS SAMPLE #SC2360	Wall	Cement Based	CHR - Chrysotile	4	Removed	18	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	UNIT NO. 2	104699	PLASTER SHEETING ASBESTOS FREE MATERIAL	Wall	Other (refer to description)	Not required	4	Removed		-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	SOUTH EXTERNAL	104584	AC PANEL ABOVE DOOR ABOVE & BELOW WINDOWS SIMILAR TO SAMPLE #SC2356	Wall	Cement Based	Not determined	4	Removed	18	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	SOUTH EXTERNAL	104758	AC SHEETING SIMILAR TO SAMPLE #SC2355	Gable/Soffit/Fascia	Cement Based	Not determined	4	Removed	18	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	NORTH EXTERNAL	104864	AC SHEETING SAMPLE #SC2355	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	FOYER	104666	AC SHEETING AND PANELS SAMPLE #SC2357	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	EX NTH BRICK WL	104590	AC PANEL ABOVE & BELOW WINDOWS PHOTO 1/2 SIMILAR TO SAMPLE #SC2356	Wall	Cement Based	Not determined	4	Removed	18	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	EAST EXTERNAL	104618	AC SHEETING SIMILAR TO SAMPLE #SC2355	Gable/Soffit/Fascia	Cement Based	Not determined	4	Removed	18	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	EAST EXTERNAL	104850	AC PANEL ABOVE DOOR ABOVE & BELOW WINDOWS SIMILAR TO SAMPLE #SC2356	Wall	Cement Based	Not determined	4	Removed	18	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	NORTH EXTERNAL	104941	AC PANELS ABOVE DOOR & BELOW FIXED WINDOWS PHOTO 1/1 SAMPLE #SC2356	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	ECEC	34E-E004-002	20655001		Ground Floor	STAFF TOILET	104639	AC SHEETING SIMILAR TO SAMPLE #SC2359	Wall	Cement Based	Not determined	4	Removed	18	-	
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	SANDPIT COVER	34E-E004-005	20655005	External	Whole Building (asbestos free)	SANDPIT COVER	430910	BUILDING CONSTRUCTED POST 1990 ÖÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	COVERED AREA 1	34E-E004-006	20655006	External	Whole Building (asbestos free)	COVERED AREA 1	430908	BUILDING CONSTRUCTED POST 1990 ÖÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	PLAY FORT AND SAILS 1	34E-E004-007	20655007	External	Whole Building (asbestos free)	PLAY FORT AND SAILS 1	430907	BUILDING CONSTRUCTED POST 1990 ÖÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	SHED - STORE 1	34E-E004-008	20655008	External	Whole Building (asbestos free)	SHED - STORE 1	430906	BUILDING CONSTRUCTED POST 1990 ÖÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	SHED - STORE 2	34E-E004-009	20655009	External	Whole Building (asbestos free)	SHED - STORE 2	430905	BUILDING CONSTRUCTED POST 1990 ÖÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	COVERED AREA 2	34E-E004-010	20655010	External	Whole Building (asbestos free)	COVERED AREA 2	430904	BUILDING CONSTRUCTED POST 1990 ÖÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
South East	BEENLEIGH FAMILY CENTRE (34E-E004) (20655000)	PLAY FORT AND SAILS 2	34E-E004-011	20655011	External	Whole Building (asbestos free)	PLAY FORT AND SAILS 2	430903	BUILDING CONSTRUCTED POST 1990 ÖÇö PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	Building built post 1990
South East	BEAUDESERT ECEC (34E-E003) (20650000)	GROUNDS	34E-E003-001	20650000	External	Site / Grounds	SITE IDENTIFICATION	179852	SHEETING TO SIGN - BEAUDESERT COMMUNICATION ECEC	Sign	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	UNIT 1	34E-E003-002	20650001	External	Ground Floor	SUN HOODS	103885	REMOVED - BUILDING DEMOLISHED FEBRUARY/MARCH 2011- SHEETING TO SUN HOODS-NORTH WEST ELEVATION	Sun Hood	Cement Based	CHR - Chrysotile	3	Removed	18	-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	UNIT 1	34E-E003-002	20650001	Internal	Ground Floor	INTERNAL WALL SHEETING	104224	REMOVED - BUILDING DEMOLISHED FEBRUARY/MARCH 2011 - WALL SHEETING - TO TOILET PARTITIONS AND OFFICE	Wall	Cement Based	CHR - Chrysotile	4	Removed	18	-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	UNIT 1	34E-E003-002	20650001	Internal	Ground Floor	INTERNAL WALL SHEETING	104030	REMOVED - BUILDING DEMOLISHED FEBRUARY/MARCH 2011 - WALL SHEETING - BETWEEN BLOCK WALLS AND CEILING	Wall	Cement Based	CHR - Chrysotile	4	Removed	18	-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	UNIT 1	34E-E003-002	20650001	Internal	Ground Floor	INTERNAL FLOOR COVERING	104161	REMOVED - BUILDING DEMOLISHED FEBRUARY/MARCH 2011 - VINYL FLOOR SHEETING	Floor Finish/Covering	Cement Based	CHR - Chrysotile	4	Removed	18	-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	UNIT 1	34E-E003-002	20650001	Internal	Ground Floor	AA									-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	UNIT 1	34E-E003-002	20650001	External	Ground Floor	SOFFIT	413407	REMOVED - BUILDING DEMOLISHED FEBRUARY/MARCH 2011 - SOFFIT SHEETING - NORTH ELEVATION	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	NA	Removed		-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	UNIT 1	34E-E003-002	20650001	External	Ground Floor	SOFFIT	104128	REMOVED - BUILDING DEMOLISHED FEBRUARY/MARCH 2011-SOFFIT SHEETING - SOUTH, EAST AND WEST ELEVATIONS	Gable/Soffit/Fascia	Cement Based	Not determined	4	Removed	18	-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	UNIT 1	34E-E003-002	20650001	External	Ground Floor	METER BOX	413479	REMOVED - BUILDING DEMOLISHED FEBRUARY/MARCH 2011 - CHIPBOARD BACKING TO METER BOX	Other (refer to description)	Other (refer to description)	Not required	NA	Removed		-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	UNIT 1	34E-E003-002	20650001	External	Ground Floor	FASCIA	104114	REMOVED - BUILDING DEMOLISHED FEBRUARY/MARCH 2011 - FASCIA SHEETING	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	NA	Removed		-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	UNIT 1	34E-E003-002	20650001	External	Ground Floor	DRAIN TRAP SURROUNDS	413386	REMOVED - BUILDING DEMOLISHED FEBRUARY/MARCH 201-DRAIN TRAPS SURROUNDS (UNDER SINK)-NORTH ELEVATION	Drains/Pipes/Flues	Cement Based	CHR - Chrysotile	4	Removed	18	-	

Region	Facility Name	Improvement	Agency Ref No	Other Ref No	Int Ext	Floor Level	Specific Location	ACM ID	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
South East	BEAUDESERT ECEC (34E-E003) (20650000)	UNIT 1	34E-E003-002	20650001	Internal	Ground Floor	INTERNAL CEILING	103996	REMOVED - BUILDING DEMOLISHED FEBRUARY/MARCH 2011 - CEILING SHEETING (ON TOP OF TRUSSES)	Ceiling	Cement Based	CHR - Chrysotile	4	Removed	18	-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	GARDEN SHED 1	34E-E003-004	20650003	Internal	Whole Building (asbestos free)	GARDEN SHED 1	104145	BUILDING CONSTRUCTED OF METAL AND TIMBER - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
South East	BEAUDESERT ECEC (34E-E003) (20650000)	GARDEN SHED 2	34E-E003-005	20650004	Internal	Whole Building (asbestos free)	GARDEN SHED 2	103886	BUILDING CONSTRUCTED OF METAL AND TIMBER - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	Not Required	NA	Not Present(Not Tested)		-	
South East	KINGSTON C&K COMM KINDERGARTEN	** Site - Grounds	54375000	54375000												-	

Warning Notice: Do not rely solely on the completeness of this Asbestos Register as all asbestos containing material may not be identified and listed, particularly in inaccessible locations and other areas not readily accessed e.g. wall cavities and ceiling spaces. If there is any doubt, presume the material contains asbestos and take appropriate precautions prior to undertaking work. Please read the information contained in the Legends at the end of the Asbestos Register.

LEGENDS

BEMIR Score

- 1 - 25:** Can be managed in-situ. Negligible hazard potential. Safe work procedures required if disturbed.
- 26 - 50:** Can be managed in-situ. Low hazard potential. Seek advice from competent person if disturbed.
- 51 - 75:** May need attention. Moderate hazard potential. Seek advice from competent person if disturbed.
- 76 - 100:** Needs attention. Hazardous. Special precautions are required if disturbed.

Physical state of ACM

- 5:** intact and stable, good condition
- 4:** intact and stable, only minor wear
- 3:** intact and stable, slight damage
- 2:** reduced stability, degrading
- 1:** unstable, severely deteriorated or major damage

The BEMIR score provides a guide to the safe management of the ACM. It is an assessment of risk that takes into consideration the form of the ACM, the condition of the ACM, and the likelihood of disturbance of the ACM. The risk assessment is conducted on the date of the asbestos survey/inspection noted in the Asbestos Register

Form of ACM

Type*

AA – Whole Building (asbestos free)	
AD – Adhesive	Bonded
CB – Cement Based	Bonded
FF – Fibrous Felt	Friable
IB – Insulation Board	Friable
LA – Lagging	Friable
LD – Low Density Board	Friable
LF – Loose Fill	Friable
MF – Mastic/Filler	Bonded
MI – Millboard	Friable
PB – Polymer Bound	Bonded
SC – Sprayed Coating	Friable
VS – Vinyl Sheeting (backing)	Friable
VT – Vinyl Tiles	Bonded
WT – Woven Textile	Friable

*Bonded forms of ACM in a deteriorated condition may become friable

Test Results

NAD – no asbestos detected
 CHR – chrysotile
 AMO – amosite
 CHR AMO – chrysotile amosite
 CHR CRO – chrysotile crocidolite
 AMO CRO – amosite crocidolite
 CHR AMO CRO – chrysotile amosite crocidolite
 Mixed – Contains more than one asbestos type**

** Test required to identify specific asbestos types